

TEST REPORT

Product Name : ENERGY STORAGE INVERTER
Model Number : HBP18-2024 HM, HBP18-3024 HM, HBP18-3524 HM, HBP18-4048 HM, HBP18-5248 HM, HBP18-5548 HM, HBP18-5248 PRO, HBP18-5548 PRO, HBP18-52481 PRO, HBP18-52482 PRO, HBP18-52483 PRO, HBP18-52484 PRO, HBP18-52485PRO, HBP18-55481 PRO, HBP18-55482 PRO, HBP18-55483 PRO, HBP18-55484 PRO, HBP18-55485 PRO

Prepared for : MUST ENERGY (GUANGDONG) TECHNOLOGY CO., LTD
Address : 1-5F, 7F, 9F, 10F of No.8 building, No.115, Zhangcha Road 1, Chancheng district, Foshan city, Guangdong Province, P.R.China

Prepared by : EMTEK (SHENZHEN) CO., LTD.
Address : Bldg 69, Majialong Industry Zone, Nanshan District, Shenzhen, Guangdong, China

Tel: (0755) 26954280
Fax: (0755) 26954282

Report Number : ENS2301100040S00201R

TEST REPORT
IEC 62109-1
Safety of Power Converter for use in Photovoltaic Power Systems
Part 1: General requirements

Report Number..... : ENS2301100040S00201R

Date of issue : March 17, 2023

Total number of pages 101 pages

Name of Testing Laboratory

preparing the Report : EMTEK (Shenzhen) Co., Ltd.

Applicant's name MUST ENERGY (GUANGDONG) TECHNOLOGY CO.,LTD

Address..... 1-5F, 7F, 9F, 10F of No.8 building, No.115, Zhangcha Road 1,
Chancheng district, Foshan city, Guangdong Province, P.R.China

Test specification:

Standard : IEC 62109-1:2010 (First Edition), EN 62109-1:2010

Test procedure..... : LVD

Non-standard test method : N/A

Test Report Form No...... : IEC62109_1B

Test Report Form(s) Originator... : VDE Testing and Certification Institute

Master TRF : Dated 2016-04

Copyright © 2016 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.


General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Test item description	ENERGY STORAGE INVERTER
Trade Mark	MUST
Manufacturer	MUST ENERGY (GUANGDONG) TECHNOLOGY CO., LTD
Address	1-5F, 7F, 9F, 10F of No.8 building, No.115, Zhangcha Road 1, Chancheng district, Foshan city, Guangdong Province, P.R.China
Model/Type reference	HBP18-2024 HM, HBP18-3024 HM, HBP18-3524 HM, HBP18-4048 HM, HBP18-5248 HM, HBP18-5548 HM, HBP18-5248 PRO, HBP18-5548 PRO, HBP18-52481 PRO, HBP18-52482 PRO, HBP18-52483 PRO, HBP18-52484 PRO, HBP18-52485PRO, HBP18-55481 PRO, HBP18-55482 PRO, HBP18-55483 PRO, HBP18-55484 PRO, HBP18-55485 PRO
Ratings	See the rating labels.



Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):	
<input checked="" type="checkbox"/> CB Testing Laboratory:	EMTEK (Shenzhen) Co., Ltd
Testing location/ address :	Bldg 69, Majialong Industry Zone, Nanshan District, Shenzhen, Guangdong, China
<input type="checkbox"/> Associated CB Testing Laboratory:	
Testing location/ address :	
Tested by (name, function, signature) :	Cloud Cui / Engineer
Approved by (name, function, signature) .. :	Angel Lan / Manager
	
<input type="checkbox"/> Testing procedure: CTF Stage 1:	
Testing location/ address :	
Tested by (name, function, signature) :	
Approved by (name, function, signature) .. :	
<input type="checkbox"/> Testing procedure: CTF Stage 2:	
Testing location/ address :	
Tested by (name + signature)..... :	
Witnessed by (name, function, signature) . :	
Approved by (name, function, signature) .. :	
<input type="checkbox"/> Testing procedure: CTF Stage 3:	
<input type="checkbox"/> Testing procedure: CTF Stage 4:	
Testing location/ address :	
Tested by (name, function, signature) :	
Witnessed by (name, function, signature) . :	
Approved by (name, function, signature) .. :	
Supervised by (name, function, signature) :	

Summary of testing:

The product has been tested according to standard IEC 62109-1:2010, EN 62109-1:2010 & IEC 62109-2:2011, EN 62109-2:2011.

- Tested for moderate conditions
- EUT is designed for altitudes not exceeding 2000m.

List of Attachments (including a total number of pages in each attachment):

This test report contains 2 parts listed in below table:

Item	Description	Pages
Part 1	IEC/EN62109-1: 2010 Test report	2-65
Part 2	IEC/EN62109-2: 2011 Test report	66-98




Test item particulars:	
Equipment mobility.....:	<input type="checkbox"/> movable <input type="checkbox"/> hand-held <input checked="" type="checkbox"/> stationary <input checked="" type="checkbox"/> fixed <input type="checkbox"/> transportable <input type="checkbox"/> for building-in
Connection to the mains.....:	<input type="checkbox"/> pluggable equipment <input type="checkbox"/> direct plug-in <input checked="" type="checkbox"/> permanent connection <input type="checkbox"/> for building-in
Environmental category.....:	<input type="checkbox"/> outdoor <input type="checkbox"/> indoor unconditional <input checked="" type="checkbox"/> indoor conditional
Over voltage category Mains.....:	<input type="checkbox"/> OVC I <input checked="" type="checkbox"/> OVC II <input type="checkbox"/> OVC III <input type="checkbox"/> OVC IV
Over voltage category PV.....:	<input type="checkbox"/> OVC I <input checked="" type="checkbox"/> OVC II <input type="checkbox"/> OVC III <input type="checkbox"/> OVC IV
Mains supply tolerance (%).....:	±10 %
Tested for power systems.....:	TN system
IT testing, phase-phase voltage (V).....:	N/A
Class of equipment.....:	<input checked="" type="checkbox"/> Class I <input type="checkbox"/> Class II <input type="checkbox"/> Class III <input type="checkbox"/> Not classified
Mass of equipment (kg).....:	MAX 17.5kg
Pollution degree.....:	PD2
Operation ambient temperature.....:	0°C ~ +50°C
IP protection class.....:	IP20
Possible test case verdicts:	
- test case does not apply to the test object.....:	N(/A, Not applicable)
- test object does meet the requirement.....:	P (Pass)
- test object does not meet the requirement.....:	F (Fail)
Testing:	
Date of receipt of test item.....:	N/A
Date (s) of performance of tests.....:	N/A


General remarks: "(See Enclosure #)" refers to additional information appended to the report. "(See appended table)" refers to a table appended to the report. Throughout this report a <input type="checkbox"/> comma / <input checked="" type="checkbox"/> point is used as the decimal separator.	
Manufacturer's Declaration per sub-clause 4.2.5 of IEC60068-2-1:	
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> Not applicable
When differences exist; they shall be identified in the General product information section.	
Name and address of factory (ies) : MUST ENERGY (GUANGDONG) TECHNOLOGY CO., LTD 1-5F, 7F, 9F, 10F of No.8 building, No.115, Zhangcha Road 1, Chancheng district, Foshan city, Guangdong Province, P.R.China	
General product information: 1) It's intended for professional incorporation into PV systems 2) The enclosure assembly was secured by screws; 3) Consider the following points before selecting where to install: It's requested to have a clearance of approx. 200mm to the front and side, 300mm above of the unit 4) Dusty conditions on the unit may impair the performance of this inverter. 5) The ambient temperature should be between 0°C and 50°C to ensure optimal operation. 6) For proper operation, please use appropriate cables. 7). All models have the similar constructions, circuit diagram and PCB layout. Unless otherwise stated, all tests were performed on model HBP18-55484 PRO which means the typical model.	

Copy of marking plate:

ENERGY STORAGE INVERTER MUST®
 Model Name: HBP1800
 MD: HBP18-2024 HM
 Operating Temperature: 0 ~ 50°C
 Protection Class: Class I
 Protection Degree: IP 20
Inverter Mode:
 Rated Power: 2000VA/2000W
 AC Output: 230VAC 50/60Hz 8.7A(Max) 1Φ
AC Charger Mode:
 AC Input: 230VAC 50/60Hz 17.7A(Max) 1Φ
 DC Output: 27VDC 30A/20A
Solar Charger Mode:
 Rated Current: 60A
 System Voltage: 24VDC
 MPPT Voltage Range: 30-120VDC
 Max. Solar Voltage (VOC): 145VDC
 Max. Charge Current: 70A
 Max.PV input Current:20A




S/N.:HBP18002024H201808230001




MADE IN CHINA

ENERGY STORAGE INVERTER MUST®
 Model Name: HBP1800
MD: HBP18-3024 HM
 Operating Temperature: 0 ~ 50°C
 Protection Class: Class I
 Protection Degree: IP 20
Inverter Mode:
 Rated Power: 3000VA/3000W
 AC Output: 230VAC 50/60Hz 13A(Max) 1Φ
AC Charger Mode:
 AC Input: 230VAC 50/60Hz 17.7A(Max) 1Φ
 DC Output: 27VDC 30A/20A
Solar Charger Mode:
 Rated Current: 60A
 System Voltage: 24VDC
 MPPT Voltage Range: 30-120VDC
 Max. Solar Voltage (VOC): 145VDC
 Max. Charge Current: 70A
 Max.PV input Current:20A




S/N.:HBP18002024H201808230001




MADE IN CHINA

ENERGY STORAGE INVERTER MUST®
 Model Name :HBP1800
 MD:HBP18-3524 HM
off-grid Mode
 Rated Power:3500VA/3500W
 DC Input :24VDC , 165A
 AC Output t :230VAC50/60Hz, 15.2A
AC Charger Mode
 AC Input :230VAC,50/60Hz,25A
 DC Output: 24VDC,80A(Max)
PV INPUT
 Rated Power:4000W
 Max Charger:100A
 Nominal Operating Voltage :360VDC
 Max.Solar Voltage(Voc) :450VDC
 MPPT Voltage Range :150-430VDC
 Max PV Current :18A



S/N.:HBP18003524201911250001



MADE IN CHINA

ENERGY STORAGE INVERTER MUST®
 Model Name: HBP1800
MD: HBP18-4048 HM
 Operating Temperature Range: -10°C~50°C
 Protection Class: Class I
 Protection Degree: IP 20
Inverter Mode:
 Rated Power: 4000VA/4000W
 DC Input: 48VDC,93A(Max)
 AC Output: 230VAC,50/60Hz,17.4A(Max)
 Output Power Factor : 1.0
AC Charger Mode:
 AC Input: 230VAC,50/60Hz,35A(Max)
 DC Output: 54VDC,60A(Max)
Solar Charger Mode:
 Rated Current: 80A
 System Voltage: 48VDC
 MPPT Voltage Range: 60~130VDC
 Max.Solar Voltage(VOC): 145VDC
Max.Charge Current:140A




S/N.:HBP18004048H201808230001



MADE IN CHINA

ENERGY STORAGE INVERTER MUST®
 Model Name:HBP1800
MD:HBP18-5248 HM
off-grid Mode
 Rated Power:5200VA/5200W
 DC Input:48VDC,135A
 AC Output:230VAC,50/60Hz,22.6A
AC Charger Mode
 AC Input:230VAC,50/60Hz,35A
 DC Output: 48VDC,60A(Max)
PV INPUT
 Rated Power: 5000W
 Max Charger:80A
 Nominal Operating Voltage:360VDC
 Max.Solar Voltage(Voc):450VDC
 MPPT Voltage Range:150-430VDC
 Max PV Current:18A




S/N.:HBP18005248H201808230001




MADE IN CHINA

ENERGY STORAGE INVERTER MUST®
 Model Name:HBP1800
MD:HBP18-5248 HM
off-grid Mode
 Rated Power:5200VA/5200W
 DC Input:48VDC,135A
 AC Output:230VAC,50/60Hz,22.6A
AC Charger Mode
 AC Input:230VAC,50/60Hz,35A
 DC Output: 48VDC,80A(Max)
PV INPUT
 Rated Power: 6000W
 Max Charger:100A
 Nominal Operating Voltage:360VDC
 Max.Solar Voltage(Voc):450VDC
 MPPT Voltage Range:150-430VDC
 Max PV Current:27A



S/N.:HBP18005248H201808230001



MADE IN CHINA

ENERGY STORAGE INVERTER

MUST®

Model Name:HBP1800

MD:HBP18-5548 HM

off-grid Mode

Rated Power:5500VA/5500W

DC Input:48VDC,130A

AC Output:230VAC,50/60Hz,23.9A

AC Charger Mode

AC Input:230VAC,50/60Hz,35A

DC Output: 48VDC,100A(Max)

PV INPUT

Rated Power: 6000W

Max Charger:120A

Nominal Operating Voltage:360VDC

Max.Solar Voltage(Voc):450VDC

MPPT Voltage Range:150-430VDC

Max PV Current:27A



S/N.:HBP18005548H201808230001



MADE IN CHINA

ENERGY STORAGE INVERTER

MUST®

Model Name:HBP1800

MD:HBP18-5248 PRO

off-grid Mode

Rated Power:5200VA/5200W

DC Input:48VDC,135A

AC Output:230VAC,50/60Hz,22.6A

AC Charger Mode

AC Input:230VAC,50/60Hz,35A

DC Output: 48VDC,60A(Max)

PV INPUT

Rated Power: 5000W

Max Charger:80A

Nominal Operating Voltage:360VDC

Max.Solar Voltage(Voc):450VDC

MPPT Voltage Range:150-430VDC

Max PV Current:18A



S/N.:HBP18005248P201911250001



MADE IN CHINA

ENERGY STORAGE INVERTER

MUST®

Model Name:HBP1800

MD:HBP18-5248 PRO

off-grid Mode

Rated Power:5200VA/5200W

DC Input:48VDC,135A

AC Output:230VAC,50/60Hz,22.6A

AC Charger Mode

AC Input:230VAC,50/60Hz,35A

DC Output: 48VDC,80A(Max)

PV INPUT

Rated Power: 6000W

Max Charger:100A

Nominal Operating Voltage:360VDC

Max.Solar Voltage(Voc):450VDC

MPPT Voltage Range:150-430VDC

Max PV Current:27A



S/N.:HBP18005248P201911250001



MADE IN CHINA

ENERGY STORAGE INVERTER

MUST®

Model Name:HBP1800

MD:HBP18-52481 PRO

off-grid Mode

Rated Power:5200VA/5200W

DC Input:48VDC,135A

AC Output:230VAC,50/60Hz,22.6A

AC Charger Mode

AC Input:230VAC,50/60Hz,35A

DC Output: 48VDC,80A(Max)

PV INPUT

Rated Power: 6000W

Max Charger:100A

Nominal Operating Voltage:360VDC

Max.Solar Voltage(Voc):450VDC

MPPT Voltage Range:150-430VDC

Max PV Current:27A



S/N.:HBP18005248P201911250001



MADE IN CHINA

ENERGY STORAGE INVERTER

MUST®

Model Name:HBP1800

MD:HBP18-52482 PRO

off-grid Mode

Rated Power:5200VA/5200W

DC Input:48VDC,135A

AC Output:230VAC,50/60Hz,22.6A

AC Charger Mode

AC Input:230VAC,50/60Hz,35A

DC Output: 48VDC,80A(Max)

PV INPUT

Rated Power: 6000W

Max Charger:100A

Nominal Operating Voltage:360VDC

Max.Solar Voltage(Voc):450VDC

MPPT Voltage Range:150-430VDC

Max PV Current:27A



S/N.:HBP18005248P201911250001



MADE IN CHINA

ENERGY STORAGE INVERTER

MUST®

Model Name:HBP1800

MD:HBP18-52483 PRO

off-grid Mode

Rated Power:5200VA/5200W

DC Input:48VDC,135A

AC Output:230VAC,50/60Hz,22.6A

AC Charger Mode

AC Input:230VAC,50/60Hz,35A

DC Output: 48VDC,80A(Max)

PV INPUT

Rated Power: 6000W

Max Charger:100A

Nominal Operating Voltage:360VDC

Max.Solar Voltage(Voc):450VDC

MPPT Voltage Range:150-430VDC

Max PV Current:27A



S/N.:HBP18005248P201911250001



MADE IN CHINA

ENERGY STORAGE INVERTER

MUST®

Model Name:HBP1800

MD:HBP18-52484 PRO

off-grid Mode

Rated Power:5200VA/5200W

DC Input:48VDC,135A

AC Output:230VAC,50/60Hz,22.6A

AC Charger Mode

AC Input:230VAC,50/60Hz,35A

DC Output: 48VDC,80A(Max)

PV INPUT

Rated Power: 6000W

Max Charger:100A

Nominal Operating Voltage:360VDC

Max.Solar Voltage(Voc):450VDC

MPPT Voltage Range:150-430VDC

Max PV Current:27A



S/N.:HBP180052484P201911250001



MADE IN CHINA

ENERGY STORAGE INVERTER

MUST®

Model Name:HBP1800

MD:HBP18-52485 PRO

off-grid Mode

Rated Power:5200VA/5200W

DC Input:48VDC,135A

AC Output:230VAC,50/60Hz,22.6A

AC Charger Mode

AC Input:230VAC,50/60Hz,35A

DC Output: 48VDC,80A(Max)

PV INPUT

Rated Power: 6000W

Max Charger:100A

Nominal Operating Voltage:360VDC

Max.Solar Voltage(Voc):450VDC

MPPT Voltage Range:150-430VDC

Max PV Current:27A



S/N.:HBP180052485P201911250001



MADE IN CHINA

ENERGY STORAGE INVERTER

Model Name:HBP1800

MD:HBP18-5548 PRO

off-grid Mode

Rated Power:5500VA/5500W

DC Input:48VDC,130A

AC Output:230VAC,50/60Hz,23.9A

AC Charger Mode

AC Input:230VAC,50/60Hz,35A

DC Output: 48VDC,100A(Max)

PV INPUT

Rated Power: 6000W

Max Charger:120A

Nominal Operating Voltage:360VDC

Max.Solar Voltage(Voc):450VDC

MPPT Voltage Range:150-430VDC

Max PV Current:27A



S/N.:HBP18005548P201911250001



MADE IN CHINA

ENERGY STORAGE INVERTER

MUST®

Model Name:HBP1800

MD:HBP18-55481 PRO

off-grid Mode

Rated Power:5500VA/5500W

DC Input:48VDC,130A

AC Output:230VAC,50/60Hz,23.9A

AC Charger Mode

AC Input:230VAC,50/60Hz,35A

DC Output: 48VDC,100A(Max)

PV INPUT

Rated Power: 6000W

Max Charger:120A

Nominal Operating Voltage:360VDC

Max.Solar Voltage(Voc):450VDC

MPPT Voltage Range:150-430VDC

Max PV Current:27A



S/N.:HBP180055482P201911250001



MADE IN CHINA

ENERGY STORAGE INVERTER

MUST®

Model Name:HBP1800

MD:HBP18-55482 PRO

off-grid Mode

Rated Power:5500VA/5500W

DC Input:48VDC,130A

AC Output:230VAC,50/60Hz,23.9A

AC Charger Mode

AC Input:230VAC,50/60Hz,35A

DC Output: 48VDC,100A(Max)

PV INPUT

Rated Power: 6000W

Max Charger:120A

Nominal Operating Voltage:360VDC

Max.Solar Voltage(Voc):450VDC

MPPT Voltage Range:150-430VDC

Max PV Current:27A



S/N.:HBP180055482P201911250001



MADE IN CHINA

ENERGY STORAGE INVERTER

MUST®

Model Name:HBP1800

MD:HBP18-55483 PRO

off-grid Mode

Rated Power:5500VA/5500W

DC Input:48VDC,130A

AC Output:230VAC,50/60Hz,23.9A

AC Charger Mode

AC Input:230VAC,50/60Hz,35A

DC Output: 48VDC,100A(Max)

PV INPUT

Rated Power: 6000W

Max Charger:120A

Nominal Operating Voltage:360VDC

Max.Solar Voltage(Voc):450VDC

MPPT Voltage Range:150-430VDC















Max PV Current:27A



S/N.:HBP180055483P201911250001



MADE IN CHINA

<p>ENERGY STORAGE INVERTER Model Name:HBP1800 MD:HBP18-55484 PRO off-grid Mode Rated Power:5500VA/5500W DC Input:48VDC,130A AC Output:230VAC,50/60Hz,23.9A AC Charger Mode AC Input:230VAC,50/60Hz,35A DC Output: 48VDC,100A(Max) PV INPUT Rated Power: 6000W Max Charger:120A Nominal Operating Voltage:360VDC Max.Solar Voltage(Voc):450VDC MPPT Voltage Range:150-430VDC Max PV Current:27A</p> <p style="text-align: right;">MUST[®]</p>  <p style="text-align: right;">S/N.:HBP180055484P201911250001</p> <p>CE       MADE IN CHINA</p>	<p>ENERGY STORAGE INVERTER Model Name:HBP1800 MD:HBP18-55485 PRO off-grid Mode Rated Power:5500VA/5500W DC Input:48VDC,130A AC Output:230VAC,50/60Hz,23.9A AC Charger Mode AC Input:230VAC,50/60Hz,35A DC Output: 48VDC,100A(Max) PV INPUT Rated Power: 6000W Max Charger:120A Nominal Operating Voltage:360VDC Max.Solar Voltage(Voc):450VDC MPPT Voltage Range:150-430VDC Max PV Current:27A</p> <p style="text-align: right;">MUST[®]</p>  <p style="text-align: right;">S/N.:HBP180055485P201911250001</p> <p>CE       MADE IN CHINA</p>
---	--



IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
4	GENERAL TESTING REQUIREMENTS		P
4.1	General		P
4.2	General conditions for testing		P
4.2.1	Sequence of tests		P
4.2.2	Reference test conditions		P
4.2.2.1	Environmental conditions	Max. 50°C rated ambient temperature tested.	P
4.2.2.2	State of equipment		P
4.2.2.3	Position of equipment	The equipment were installed in accordance with the manufacturer's instructions, in the configuration that results in the worst-case test conditions	P
4.2.2.4	Accessories	No accessories or operator interchangeable parts	N/A
4.2.2.5	Covers and removable parts		N/A
4.2.2.6	Mains supply a) Voltage: b) Frequency: c) Polarity: d) Earthing: e) Over-current Protection:	230V (90% to 110% tolerance), 50/60 Hz, single phase, TN system considered. (see appended table 4.2.2.6)	P
4.2.2.7	Supply ports other than the mains	DC input	P
4.2.2.7.1	Photovoltaic supply sources a) Open circuit voltage: b) Short-circuit current:	(see appended table 4.2.2.7)	P
4.2.2.7.2	Battery inputs	No batteries for energy storage	N/A
4.2.2.8	Conditions of loading for output ports	DC-AC inverter. a.c. output port was loaded with linear loads to obtain the maximum rated output power. Continuous operation ratings, until steady conditions are established.	P
4.2.2.9	Earthing terminals	Protective conductor terminal was connected to earth. No functional earth terminal.	P
4.2.2.10	Controls		P
4.2.2.11	Available short circuit current		N/A

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
4.3	Thermal testing	(see appended table 4.3)	P
4.3.1	General		P
4.3.2	Maximum temperatures	Tests of equipment rated for use in ambient temperatures up to 50°C	P
4.3.2.1	General		P
4.3.2.2	Touch temperatures		P
4.3.2.3	Temperature limits for mounting surfaces		P
4.4	Testing in single fault condition		P
4.4.1	General		P
4.4.2	Test conditions and duration for testing under fault conditions		P
4.4.2.1	General		P
4.4.2.2	Duration of tests		P
4.4.3	Pass/fail criteria for testing under fault conditions		P
4.4.3.1	Protection against shock hazard		P
4.4.3.2	Protection against the spread of fire		P
4.4.3.3	Protection against other hazards		P
4.4.3.4	Protection against parts expulsion hazards		P
4.4.4	Single Fault conditions to be applied		P
4.4.4.1	Component fault tests	(see appended table)	P
4.4.4.2	Equipment or parts for short-term or intermittent operation	Not for short-term or intermittent operation	N/A
4.4.4.3	Motors	DC fan used inside	P
4.4.4.4	Transformer short circuit tests	(see appended table)	P
4.4.4.5	Output short circuit		P
4.4.4.6	Backfeed current test		P
4.4.4.7	Output overload		P
4.4.4.8	Cooling system failure	Blanketing test for the heatsink according to IEC 62109-2 Clause 4.4.4.17	P
4.4.4.9	Heating devices	No heating devices used	N/A
4.4.4.10	Safety interlock	No safety interlock	N/A
4.4.4.11	Reverse d.c. connections	The unit cannot start-up, no input power, no damage, no hazard.	P
4.4.4.12	Voltage selector mismatch	No voltage selector	N/A
4.4.4.13	Mis-wiring with incorrect phase sequence or polarity		P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
4.4.4.14	PWB short-circuit test		P
4.5	Humidity preconditioning	(see appended table 7.5)	P
4.5.1	General		P
4.5.2	Conditions	95% R.H. 40°C. 48H	P
4.6	Voltage Backfeed protection		P
4.6.1	Backfeed tests under normal conditions	See Clause 4.6.3	P
4.6.2	Backfeed tests under single-fault condntions		P
4.6.3	Compliance with backfeed tests	Backfeed voltage and energy protection.	P
4.7	Electrical ratings tests		P
4.7.1	Input ratings		P
4.7.1.1	Measurement requirements for DC input ports		P
4.7.2	Output ratings		P


5	MARKING AND DOCUMENTATION		P
5.1	Marking		P
5.1.1	General		P
	Equipment shall bear markings as specified in 5.1 and 5.2	Label are marked on the PCE and graphic symbol is explained in user manual	P
	Graphic symbols may be used and shall be in accordance with Annex C or IEC 60417 as applicable.		P
	Graphic symbols shall be explained in the documentation provided with the PCE.		P
5.1.2	Durability of markings		P
	Markings required by this clause to be located on the PCE shall remain clear and legible under conditions of NORMAL USE and resist the effects of cleaning agents specified by the manufacturer	The label was subjected to the permanence of marking test. The label was rubbed with cloth soaked with water for 30 sec. And then again for 30 sec. With the cloth soaked with petroleum spirit. After this test there was no damage to the label. The marking on the label did not fade. There was no curling or lifting of the label edge.	P
5.1.3	Identification		P
	The equipment shall, as a minimum, be permanently marked with:		P
	a) the name or trade mark of the manufacturer or	With manufacturer	P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	supplier		
	b) model number, name or other means to identify the equipment		P
	c) a serial number, code or other marking allowing identification of manufacturing location and the manufacturing batch or date within a three month time period.	Within three months	P
5.1.4	Equipment ratings	See below	P
	Unless otherwise specified in another part of IEC 62109, the following ratings, as applicable shall be marked on the equipment:		P
	- input voltage, type of voltage (a.c. or d.c.), frequency, and max. continuous current for each input	Refer to the marking label	P
	- output voltage, type of voltage (a.c. or d.c.), frequency, max. continuous current, and for a.c. outputs, either the power or power factor for each output	Refer to the marking label	P
	- the ingress protection (IP) rating as in 6.3 below	IP20	P
5.1.5	Fuse identification	The fuse is secure on the PCB. Covered by the potting compound filled with in the enclosure. It cannot access by operator.	P
	Marking shall be located adjacent to each fuse or fuseholder, or on the fuseholder, or in another location provided that it is obvious to which fuse the marking applies, giving the fuse current rating and where fuses of different voltage rating value could be fitted, the fuse voltage rating.		P
	Where fuses with special fusing characteristics such as time delay or breaking capacity are necessary, the type shall also be indicated		P
	For fuses not located in operator access areas and for soldered-in fuses located in operator access areas, it is permitted to provide an unambiguous cross-reference (for example, F1, F2, etc.) to the servicing instructions which shall contain the relevant information.		P
5.1.6	Terminals, Connections, and Controls		P
	If necessary for safety, an indication shall be given of the purpose of Terminals, connectors, controls, and indicators, and their various positions, including any connections for coolant fluids such as water and drainage. The symbols in Annex C may be used, and where there is insufficient space, symbol 9 of Annex C may be	Symbol 9 are marked on the PCE and user manual indicate the installation and safety of connection of connector, control and indicator	P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	used.		
	Push-buttons and actuators of emergency stop devices, and indicator lamps used only to indicate a warning of danger or the need for urgent action shall be coloured red.	No emergency stop	N/A
	A multiple-voltage unit shall be marked to indicate the particular voltage for which it is set when shipped from the factory. The marking is allowed to be in the form of a paper tag or any other nonpermanent material.	No emergency stop	N/A
	A unit with d.c. terminals shall be plainly marked indicating the polarity of the connections, with:	See below	P
	– the sign “+” for positive and “-”, for negative; or	The input PV terminals for each module and whole unit are moulded with sign “+” for positive and “-” for negative	P
	– a pictorial representation illustrating the proper polarity where the correct polarity can be unambiguously determined from the representation	Not provided	N/A
5.1.6.1	Protective Conductor Terminals		P
	The means of connection for the protective earthing conductor shall be marked with:	The PE terminal is connected via AC output cable	p
	symbol 7 of Annex C; or		P
	the letters “PE”; or		N/A
	the colour coding green-yellow.		P
5.1.7	Switches and circuit-breakers	Approved switch was used for all models.	P
	The on and off-positions of switches and circuits breakers shall be clearly marked. If a push-button switch is used as the power switch, symbols 10 and 16 of Annex C may be used to indicate the on-position, or symbols 11 and 17 to indicate the off-position, with the pair of symbols (10 and 16, or 11 and 17) close together.	“ON” indicated the on-position of DC switch. “OFF” indicated the off- position of DC switch	P
5.1.8	Class II Equipment	Class I	N/A
	Equipment using Class II protective means throughout shall be marked with symbol 12 of Annex C. Equipment which is only partially protected by DOUBLE INSULATION or REINFORCED INSULATION shall not bear symbol 12 of Table Annex C.		N/A
	Where such equipment has provision for the connection of an earthing conductor for functional reasons (see 7.3.6.4) it shall be marked with symbol 6 of Annex C		N/A

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
5.1.9	Terminal boxes for External Connections	No such terminal box	N/A
	Where required by note 1 of Table 2 as a result of high temperatures of terminals or parts in the wiring compartment, there shall be a marking, visible beside the terminal before connection, of either:	The wiring used inside the PCE is within the rating	N/A
	a) the minimum temperature Rating and size of the cable to be connected to the TERMINALS; or		N/A
	b) a marking to warn the installer to consult the installation instruction. Symbol 9 of Table D-1 is an acceptable marking		N/A
5.2	Warning markings		P
5.2.1	Visibility and legibility requirements for warning markings		P
	Warning markings shall be legible, and shall have minimum dimensions as follows:		P
	- Printed symbols shall be at least 2,75 mm high		P
	- Printed text characters shall be at least 1.5 mm high and shall contrast in colour with the background		P
	- Symbols or text that are moulded, stamped or engraved in a material shall have a character height of at least 2,0 mm, and if not contrasting in colour from the background, shall have a depth or raised height of at least 0,5 mm.		P
	If it is necessary to refer to the instruction manual to preserve the protection afforded by the equipment, the equipment shall be marked with symbol 9 of Annex C	The manual provide necessary information for the warning marking	P
	Symbol 9 of Annex C is not required to be used adjacent to symbols that are explained in the manual		P
5.2.2	Content for warning markings		P
5.2.2.1	Ungrounded heatsinks and similar parts	Grounded heatsink and metal enclosure	N/A
	An ungrounded heat sink or other part that may be mistaken for a grounded part and involves a risk of electric shock in accordance with 7.3 shall be marked with symbol 13 of Annex C, or equivalent. The marking may be on or adjacent to the heatsink and shall be clearly visible when the PCE is disassembled to the extent that a risk of contact with the heatsink exists.		N/A
5.2.2.2	Hot Surfaces		P
	A part of the PCE that exceeds the temperature	Symbol 14 marked on PCE	P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	limits specified in 4.3.2 shall be marked with symbol 14 of Annex C or equivalent.		
5.2.2.3	Coolant	Coolant is not used	N/A
	A unit containing coolant that exceeds 70 °C shall be legibly marked externally where readily visible after installation with symbol 15 of Annex C. The documentation shall provide a warning regarding the risk of burns from hot coolant, and either:		N/A
	a) statement that coolant system servicing is to be done only by SERVICE PERSONNEL, or		N/A
	b) instructions for safe venting, draining, or otherwise working on the cooling system, if these operations can be performed without OPERATOR access to HAZARDS internal to the equipment		N/A
5.2.2.4	Stored energy		P
	Where required by 7.3.9.2 or 7.4.2 the PCE shall be marked with Symbol 21 of Annex C and the time to discharge capacitors to safe voltage and energy levels shall accompany the symbol.	Symbol 21 is marked on PCE	P
5.2.2.5	Motor guarding		P
	Where required by 8.2 a marking shall be provided where it is visible to service personnel before removal of a guard, warning of the hazard and giving instructions for safe servicing (for example disconnection of the source before removing the guard).		N/A
5.2.3	Sonic hazard markings and instructions	Hazardous noise is not produced	N/A
	If required by 10.2.1 a PCE shall:		N/A
	a) be marked to warn the operator of the sonic pressure hazard; or		N/A
	b) be provided with installation instructions that specify how the installer can ensure that the sound pressure level from equipment at its point of use after installation, will not reach a value, which could cause a hazard. These instructions shall include the measured sound pressure level, and shall identify readily available and practicable protective materials or measures which may be used.		N/A
5.2.4	Equipment with multiple sources of supply	PV array and AC mains, battery, generator	P
	A PCE with connections for multiple energy sources shall be marked with symbol 13 of Annex C and the manual shall contain the information required in 5.3.4.	Symbol 13 provided on PCE	P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	The symbol shall be located on the outside of the unit or shall be prominently visible behind any cover giving access to hazardous parts.		P
5.2.5	Excessive touch current		N/A
	Where required by 7.3.6.3.7 the PCE shall be marked with symbol 15 of Annex C. See also 5.3.2 for information to be provided in the installation manual.		N/A
5.3	Documentation		P
5.3.1	General		P
	The documentation provided with the PCE shall provide the information needed for the safe operation, installation, and (where applicable) maintenance of the equipment. The documentation shall include the items required in 5.3.2 through 5.3.4, and the following:		P
	a) explanations of equipment makings, including symbols used		P
	b) location and function of terminals and controls		P
	c) all ratings or specifications that are necessary to safely install and operate the PCE, including the following environmental ratings along with an explanation of their meaning and any resulting installation requirements:		P
	- ENVIRONMENTAL CATEGORY as per 6.1	Indoor	P
	- WET LOCATIONS classification for the intended external environment as per 6.1	Not wet location	P
	- POLLUTION DEGREE classification for the intended external environment as per 6.2	2	P
	- INGRESS PROTECTION rating as per 6.3	IP20	P
	- Ambient temperature and relative humidity ratings	Max. 50°C and 95%RH	P
	- MAXIMUM altitude rating	Up to 2000 m	P
	- OVERVOLTAGE CATEGORY assigned to each input and output port as per 7.3.7.1.2, accompanied by guidance regarding how to ensure that the installation complies with the required overvoltage categories;	OVC II (PV), OVC II (Mains)	P
	d) a warning that when the photovoltaic array is exposed to light, it supplies a d.c. voltage to the PCE		P
5.3.1.1	Language	English provide	P
	Instructions related to safety shall be in a language that is acceptable in the country where	For other country language, further evaluation is needed	P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	the equipment is to be installed.		
5.3.1.2	Format		P
	In general, the documentation must be provided in printed form and is to be delivered with the equipment.	Printed form provided and is to be delivered with equipment	P
	For equipment which requires the use of a computer for both installation and operation, documentation may be provided in electronic format without accompanying printed format.		P
5.3.2	Information related to installation		P
	The documentation shall include installation and where applicable, specific commissioning instructions and, if necessary for safety, warnings against hazards which could arise during installation or commissioning of the equipment. The information provided shall include:		P
	a) assembly, location, and mounting requirements;		P
	b) ratings and means of connection to each source of supply and any requirements related to wiring and external controls, colour coding of leads, disconnection means, or overcurrent protection needed, including instructions that the installation position shall not prevent access to the disconnection means;		P
	c) ratings and means of connection of any outputs from the PCE, and any requirements related to wiring and external controls, colour coding of leads, or overcurrent protection needed;		P
	d) explanation of the pin-out of connectors for external connections, unless the connector is used for a standard purpose (e.g. RS 232)		P
	e) ventilation requirements;		P
	f) requirements for special services, for example cooling liquid;	No cooling liquid or other special service	N/A
	g) instructions and information relating to sound pressure level if required by 10.2.1;	<60 dBA	P
	h) where required by 14.8.1.3, instructions for the adequate ventilation of the room or location in which PCE containing vented or valve-regulated batteries is located, to prevent the accumulation of hazardous gases;	No such battery	N/A
	i) tightening torque to be applied to wiring terminals;		P
	j) values of backfeed short-circuit currents available from the PCE on input and output		P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	conductors under fault conditions, if those currents exceeds the max. rated current of the circuit, as per 4.4.4.6;		
	k) for each input to the PCE, the max value of short-circuit current available from the source, for which the PCE is designed; and		P
	l) compatibility with RCD and RCM;	Internal RCD devices is used	N/A
	m) instructions for protective earthing, including the information required by 7.3.6.3.7 if a second protective earthing conductor is to be installed:	Touch current not exceed limit	N/A
	n) where required by 7.3.8, the installation instructions shall include the following or equivalent wording:	Internal RCD devices is used	N/A
	“This product can cause a d.c. current in the external protective earthing conductor. Where a residual current-operated protective (RCD) or monitoring (RCM) device is used for protection in a case of direct or indirect contact, only an RCD or RCM of Type B is allowed on the supply side of this product.”		N/A
	o) for PCE intended to charge batteries, the battery nominal voltage rating, size, and type		N/A
	p) PV array configuration information, such as ratings, whether the array is to be grounded or floating, any external protection devices needed, etc.		P
5.3.3	Information related to operation		P
	Instructions for use shall include any operating instructions necessary to ensure safe operation, including the following, as applicable:		P
	- Instructions for adjustment of controls including the effects of adjustment;		P
	- Instructions for interconnection to accessories and other equipment, including indication of suitable accessories, detachable parts and any special materials;		P
	- Warnings regarding the risk of burns from surfaces permitted to exceed the temperature limits of 4.3.2 and required operator actions to reduce the risk; and		P
	- Instructions, that if the equipment is used in a manner not specified by the manufacturer, the protection provided by the equipment may be impaired.		P
5.3.4	Information related to maintenance		P
	Maintenance instructions shall include the		P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	following:		
	- Intervals and instructions for any preventive maintenance that is required to maintain safety (for example air filter replacement or periodic re-tightening of terminals);		P
	- Instructions for accessing operator access areas, if any are present, including a warning not to enter other areas of the equipment;		P
	- Part numbers and instructions for obtaining any required operator replaceable parts;	No replaceable parts	N/A
	- Instructions for safe cleaning (if recommended)		P
	- Where there is more than one source of supply energizing the PCE, information shall be provided in the manual to indicate which disconnect device or devices are required to be operated in order to completely isolate the equipment.		P
5.3.4.1	Battery maintenance	No energy storage battery inside	N/A
	Where required by 14.8.5, the documentation shall include the applicable items from the following list of instructions regarding maintenance of batteries:		N/A
	- Servicing of batteries should be performed or supervised by personnel knowledgeable about batteries and the required precautions		N/A
	- When replacing batteries, replace with the same type and number of batteries or battery packs		N/A
	- General instructions regarding removal and installation of batteries		N/A
	- CAUTION: Do not dispose of batteries in a fire. The batteries may explode.		N/A
	- CAUTION: Do not open or damage batteries. Released electrolyte is harmful to the skin and eyes. It may be toxic.		N/A
	- CAUTION: A battery can present a risk of electrical shock and high short-circuit current. The following precautions should be observed when working on batteries:		N/A
	a) Remove watches, rings, or other metal objects.		N/A
	b) Use tools with insulated handles.		N/A
	c) Wear rubber gloves and boots.		N/A
	d) Do not lay tools or metal parts on top of batteries		N/A
	e) Disconnect charging source prior to connecting		N/A

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	or disconnecting battery terminals		
	f) Determine if battery is inadvertently grounded. If inadvertently grounded, remove source from ground. Contact with any part of a grounded battery can result in electrical shock. The likelihood of such shock can be reduced if such grounds are removed during installation and maintenance (applicable to equipment and remote battery supplies not having a grounded supply circuit).		N/A

6	Environmental requirements and conditions		P
	The manufacturer shall rate the PCE for the following environmental conditions:		P
	- ENVIRONMENTAL CATEGORY, as in 6.1 below	Indoor use	P
	- Suitability for WET LOCATIONS or not	Suitability for wet locations	P
	- POLLUTION DEGREE rating in 6.2 below	PD2	P
	- INGRESS PROTECTION (IP) rating, as in 6.3 below	IP20	P
	- Ultraviolet (UV) exposure rating, as in 6.4 below		N/A
	- Ambient temperature and relative humidity ratings, as in 6.5 below		P
6.1	Environmental categories and minimum environmental conditions		P
6.1.1	Outdoor		P
6.1.2	Indoor, unconditioned		N/A
6.1.3	Indoor, conditioned		N/A
6.2	Pollution degree	PD2	P
6.3	Ingress Protection	IP20	P
6.4	UV exposure		P
6.5	Temperature and humidity		P

7	Protection against electric shock and energy hazards		P
7.1	General		P
7.2	Fault conditions	Normal and single fault condition are considered	P
7.3	Protection against electric shock		P
7.3.1	General	In the PCE the earthed metal enclosure is evaluated by means of basic insulation from DVC C circuit.	P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
		Unearthed accessible parts are evaluated by means of reinforce insulation from DVC C. accessible parts are evaluated by means of reinforce insulation from DVC C. DVC C: The PV input and mains output. DVC A: the communication interface	
7.3.2	Decisive voltage classification		P
7.3.2.1	Use of decisive voltage class (DVC)	Working voltage and protective measures are considered.	P
7.3.2.2	Limits of DVC (according table 6)	Wet location is considered for PCE outside only	P
7.3.2.3	Short-terms limits of accessible voltages under fault conditions		P
7.3.2.4	Requirements for protection (according table 7)	Single fault condition is considered. Accessible earthed conductive parts are separated from DVC-C circuits by basic insulation. Accessible unearthed conductive parts separated from DVC C circuit by reinforce insulation	P
7.3.2.5	Connection to PELV and SELV circuits	The external signal communication interface are considered as SELV	P
7.3.2.6	Working voltage and DVC		P
7.3.2.6.1	General	Transients and voltage fluctuations are disregarded. And worst case normal operating condition is considered	P
7.3.2.6.2	AC working voltage (see Figure 2)	considered	P
7.3.2.6.3	DC working voltage (see Figure 3)	Max. DC open voltage:48 V	P
7.3.2.6.4	Pulsating working voltage (see Figure 4)		N/A
7.3.3	protective separation	See description in Cl. 7.3.1	P
	Protective separation shall be achieved by:		P
	double or reinforced insulation, or		P
	protective screening, i.e. by a conductive screen connected to earth by protective bonding in the PCE, or connected to the protective earth		P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	conductor itself, whereby the screen is separated from live parts by at least basic insulation, or		
	protective impedance comprising limitation of current per 7.3.5.3 and of discharged energy per 7.3.5.4, or		P
	limitation of voltage according to 7.3.5.4.		N/A
	The protective separation shall be fully and effectively maintained under all conditions of intended use of the PCE		P
7.3.4	Protection against direct contact		P
7.3.4.1	General		P
	Protection against direct contact is employed to prevent persons from touching live parts that do not meet the requirements of 7.3.5 and shall be provided by one or more of the measure given in 7.3.4.2 (enclosures and barriers) and 7.3.4.3 (insulation).	Enclosure provided	P
	Open type sub-assemblies and devices do not require protective measures against direct contact but the instruction provided with the equipment must indicate that such measures must be provided in the end equipment or in the installation.	End use product	N/A
	Product intended for installation in CLOSED ELECTRICAL OPERATING AREAS, (see 3.9) need not have protective measures against direct contact, except as required by 7.3.4.2.4.	No use under this condition	N/A
7.3.4.2	Protection by means of enclosures and barriers		P
	The following requirements apply where protection against contact with live parts is provided by enclosures or barriers, not by insulation in accordance with 7.3.4.3.	Enclosure provided to prevent access to inside live parts	P
7.3.4.2.1	General		P
	Parts of enclosures and barriers that provide protection in accordance with these requirements shall not be removable without the use of a tool (see 7.3.4.2.3).	Secured by screws	P
	Polymeric materials used to meet these requirements shall also meet the requirements of 13.6		P
7.3.4.2.2	Access probe criteria		P
	Protection is considered to be achieved when the separation between the test probes and live parts, when tested as described below, is as follows:	The communication interface is considered as DVC A	P
	a) decisive voltage classification A, (DVC A) - the	The DVC B circuit is not	P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	probe may touch the live parts	accessible by probe	
	b) decisive voltage classification B, (DVC B) - the probe must not touch bare live parts	The DVC C circuit is not accessible by probe	P
	c) decisive voltage classification C, (DVC C) – the probe must have adequate clearance to live parts, based on the clearance for Basic insulation using the recurring peak working voltage involved,		P
7.3.4.2.3	Access probe tests		P
	Compliance with 7.3.4.2.1 is checked by all of the following:		P
	a) Inspection; and		P
	b) Tests with the test finger (Figure D.1) and test pin (Figure D.2) of 0E, the results of which shall comply with the requirements of 7.3.4.2.1 a), b), and c) as applicable. Probe tests are performed on openings in the enclosures after removal of parts that can be detached or opened by an operator without the use of a tool, including fuseholders, and with operator access doors and covers open. It is permitted to leave lamps in place for this test. Connectors that can be separated by an operator without use of a tool, shall also be tested during and after disconnection. Any movable parts are to be put in the most unfavorable position.		P
	The test finger and the test pin are applied as above, without appreciable force, in every possible position, except that floor-standing equipment having a mass exceeding 40 kg is not tilted.		P
	Equipment intended for building-in or rack mounting, or for incorporation in larger equipment, is tested with access to the equipment limited according to the method of mounting detailed in the installation instructions.		N/A
	c) Openings preventing the entry of the jointed test finger (Figure E-1 of 0E) during test b) above, are further tested by means of straight unjointed test finger (Figure E-3 of 0E), applied with a force of 30 N. If the unjointed finger enters, the test with the jointed finger is repeated except that the finger is applied using any necessary force up to 30 N.		P
	d) In addition to a) – c) above, top surfaces of enclosure shall be tested with the IP3X probe of IEC 60529. The test probe shall not penetrate the top surface of the enclosure when probed from the vertical direction $\pm 5^\circ$ only.		P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
7.3.4.2.4	Service access areas	Inside PCE are not intentionally touched with energized part when, installation and maintenance. Symbol 21 of Annex C are marked on PCE and explained in user manual	P
7.3.4.3	Protection by means of insulation of live parts	The earthed enclosure is with basic insulation from the live parts inside	P
	Where the requirements of 7.3.4.2 are not met, live parts shall be provided with insulation if:		P
	their working voltage is greater than the maximum limit of decisive voltage class A, or		P
	for a DVC A or B circuit, protective separation from adjacent circuit of DVC C is not provided (see note “‡” under Table 7)		P
7.3.5	Protection in case of direct contact	The communication interface are direct contact and evaluated with reinforce insulation from live parts	P
7.3.5.1	General		P
	Protection in case of direct contact is required to ensure that contact with live parts does not produce a shock hazard.		P
	The protection against direct contact according to 7.3.4 is not required if the circuit contacted is separated from other circuits according to 7.3.2.3, and:	Considered	P
	- is of decisive voltage class A and complies with 7.3.5.2, or	The communication interface is DVC A and reinforce insulation from the live parts by means of isolation transformer and opto-coupler	P
	- is provided with protective impedance according to 7.3.5.3, or		N
	- is limited in voltage according to 7.3.5.4		N/A
	In addition to the measures as given in 7.3.5.2 to 7.3.5.4, it shall be ensured that in the event of error or polarity reversal of connectors no voltages that exceed DVC A can be connected into a circuit with protective separation. This applies for example to plug-in-sub-assemblies or other plug-in devices which can be plugged-in without the use of a tool (key) or which are accessible without the use of a tool.	Considered	P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Conformity is checked by visual inspection and trial insertion.		P
7.3.5.2	Protection using decisive voltage class A	The communication interface is DVC A and reinforce insulation from the live parts by means of isolation transformer and opto-coupler	P
7.3.5.3	Protection by means of protective impedance	Sampling resistors in series connected between PV and PE considering as protective impedance.	P
	Circuits and conductive parts do not require protection against direct contact if any connection to circuits of DVC-B or DVC-C is through protective impedance, and the accessible circuit or part is otherwise provided with protective separation from circuits of DVC-B or DVC-C according 7.3.3.		P
7.3.5.3.1	Limitation of current through protective impedance		P
	The current available through protective impedance to earth and between simultaneously accessible parts, measured at the accessible live parts, shall not exceed a value of 3,5 mA a.c. or 10 mA d.c. under normal and single-fault conditions.	Touch current less than 3,5 mA at normal and single fault conditions	P
7.3.5.3.2	Limitation of discharging energy through protective impedance		P
	The discharging energy available between simultaneously accessible parts protected by protective impedance shall not exceed the charging voltage and capacitance limits given in Table 9, which applies to both wet and dry locations, under normal and single fault conditions. Refer to figure 8.		P
7.3.5.4	Protection by means of limited voltages	No such design	N/A
	That portion of a circuit that has its voltage reduced to DVC-A by a voltage divider that complies with the following requirements, and that is otherwise provided with protective separation from circuits of DVC-B or DVC-C according to 7.3.3, does not require protection against direct contact.		N/A
	The voltage divider shall be designed so that under normal and single fault conditions, including faults in the voltage division circuit, the voltage across the output of the voltage divider does not exceed the limit for DVC-A.		N/A

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	This type of protection shall not be used in case of protective class II or unearthed circuits, because it relies on protective earth being connected.		N/A
7.3.6	Protection against indirect contact		P
7.3.6.1	General		P
	Protection against indirect contact is required to prevent shock- hazardous current being accessible from conductive parts during an insulation failure. This protection shall comply with the requirements for protective class I (basic insulation plus protective earthing), class II (double or reinforced insulation) or class III (limitation of voltages)	Class I also with reinforce insulation design inside PCE	P
	That part of a PCE meets the requirements of 7.3.6.2 and 7.3.6.3 is defined as protective class I	The earthed metal enclosure meet this requirement	P
	That part of a PCE meets the requirements of 7.3.6.4 is defined as protective class II.	The communication interface is reinforce insulated from live parts inside	P
	That part of PCE which meets the requirements of decisive voltage class A and in which no hazardous voltages are derived, is defined as protective class III. No shock hazard is present in such circuits.		N/A
	Where protection against indirect contact is dependent on means provided during installation, the installation instructions shall provide details of the required means and shall indicate the associated hazards.	The manual require the PCE must be securely earthed	P
7.3.6.2	Insulation between live parts and accessible conductive parts	See Cl. 7.3.7.4 and Cl. 7.3.7.5	P
	Accessible conductive parts of equipment shall be separated from live parts by insulation meeting the requirements of Table 7 or by clearances as specified in 7.3.7.4 and creepages as specified in 7.3.7.5		P
7.3.6.3	Protective class I – Protective bonding and earthing		P
7.3.6.3.1	General		P
	Equipment of protective class I shall be provided with protective earthing, and with protective bonding to ensure electrical contact between accessible conductive parts and the means of connection for the external protective earthing conductor, except bonding is not required for:		P
	a) accessible conductive parts that are protected		N/A

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	by one of the measures in 7.3.5.2 to 7.3.5.4, or		
	b) accessible conductive parts are separated from live parts of DVC-B or -C using double or reinforced insulation.		P
7.3.6.3.2	Requirements for protective bonding		P
	Electrical contact with the means of connection of the external protective earthing conductor shall be achieved by one or more of the following means:		P
	a) through direct metallic contact;		P
	b) through other conductive parts which are not removed when the PCE or sub-units are used as intended ;		N/A
	c) through a dedicated protective bonding conductor;		P
	d) through other metallic components of the PCE		N/A
	Where direct metallic contact is used and one or both of the parts involved is painted or coated, the paint or coating shall be removed in the area of contact, or reliably penetrated, to ensure metal to metal contact.		P
	For moving or removable parts, hinges or sliding contacts designed and maintained to have a low resistance are examples of acceptable means if they comply with the requirements of 7.3.6.3.3.		N/A
	Metal ducts of flexible or rigid construction and metallic sheaths shall not be used as protective bonding conductors, unless the device or material has been investigated as suitable for protective bonding purposes.		N/A
7.3.6.3.3	Rating of protective bonding		P
	Protective bonding shall withstand the highest thermal and dynamic stresses that can occur to the PCE item(s) concerned when they are subjected to a fault connecting live parts to accessible conductive parts. The protective bonding shall remain effective for as long as a fault to the accessible conductive parts persists or until an upstream protective device removes power from the part.		P
	Protective bonding shall meet following requirements:		P
	a) For PCE with an overcurrent protective device rating of 16 A or less, the impedance of the protective bonding means shall not exceed 0,1 Ω during or at the end of the test below.		N/A

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	b) For PCE with an overcurrent protective device rating of more than 16 A, the voltage drop in the protective bonding test shall not exceed 2,5 V during or at the end of the test below.	Test current: 260 A Test time: 10 minutes the voltage drop: 1.84V	P
	As alternative to a) and b) the protective bonding may designed according to the requirements for the external protective earthing conductor in 7.3.6.3.5, in which case no testing is required.	Protective bonding wire size is same as output cable	P
	The impedance of protective bonding means shall be checked by passing a test current through the bond for a period of time as specified below. The test current is based on the rating of the overcurrent protection for the equipment or part of the equipment under consideration, as follows:		P
	a) For pluggable equipment type A, the overcurrent protective device is that provided external to the equipment (for example, in the building wiring, in the mains plug or in an equipment rack);		N/A
	b) For pluggable equipment type B and fixed equipment, the maximum rating of the overcurrent protective device specified in the equipment installation instructions to be provided external to the equipment;		N/A
	c) For a circuit or part of the equipment for which an overcurrent protective device is provided as part of the equipment, the rating of the provided overcurrent device.		P
	Voltages are measured from the protective earthing terminal to all parts whose protective bonding means are being considered. The impedance of the protective earthing conductor is not included in the measurement. However, if the protective earthing conductor is supplied with the equipment, it is permitted to include the conductor in the test circuit but the measurement of the voltage drop is made only from the main protective earthing terminal to the accessible part required to be earthed.	Measured from the farthest part of earthed metal enclosure to the input earth terminal	P
	On equipment where the protective earth connection to a subassembly or to a separate unit is part of a cable that also supplies power to that subassembly or unit, the resistance of the protective bonding conductor in that cable is not included in the protective bond impedance measurements for the subassembly or separate unit, as shown in Figure 11. However, this option is only permitted if the cable is protected by a suitably rated protective device that takes into	Figure 11 used	P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	account the size of the conductor. Otherwise the impedance of the protective bonding conductor between the separate units is to be included, by measuring to the protective earthing terminal where the power source enters the first unit in the system, as shown in Figure 12.		
7.3.6.3.3.1	Test current, duration, and acceptance criteria	Protective bonding size is same as output cable	P
	The test current, duration of the test and acceptance criteria are as follows:		P
	a) For PCE with an overcurrent protective device rating of 16 A or less, the test current is 200% of the overcurrent protective device rating, but not less than 32 A, applied for 120s. The impedance of the protective bonding means during and at the end of the test shall not exceed 0,1 Ω .		N/A
	b) For PCE with an overcurrent protective device rating of more than 16 A, the test current is 200% of the overcurrent protective device rating and the duration of the test is as shown in Table 10 below. The voltage drop in the protective bonding means, during and at the end of the test, shall not exceed 2,5 V.		P
	c) During and after the test, there shall be no melting, loosening, or other damage that would impair the effectiveness of the protective bonding means.		P
	The test current is derived from an a.c or d.c supply source, the output of which is not earthed.	DC supply	P
	As an alternative to Table 10, where the time-current characteristic of the overcurrent protective device that limits the fault current in the protective bonding means is known because the device is either provided in the equipment or fully specified in the installation instructions, the test duration may be based on that specific device's time-current characteristic,. The tests are conducted for a duration corresponding to the 200% current value on the time-current characteristic.		P
7.3.6.3.4	Protective bonding impedance (routine test)		N/A
	If the continuity of the protective bonding is achieved at any point by a single means only (for example a single conductor or single fastener), or if the PCE is assembled at the installation location, then the impedance of the protective bonding shall also be tested as a routine test. The test shall be as in 7.3.6.3.3, except for the following:	Declared by Manufacturer and working instruction checked during factory inspection	N/A

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	the test current may be reduced to any convenient value greater than 10 A sufficient to allow measurement or calculation of the impedance of the protective bonding means:		N/A
	the test duration may be reduced to no less than 2 s		N/A
	For equipment subject to the type test in 7.3.6.3.3.1a), the impedance during the routine test shall not exceed 0,1Ω.		N/A
	For equipment subject to the type test in 7.3.6.3.3.1b) the impedance during the routine test shall not exceed 2,5 V divided by the test current required by 7.3.6.3.3.1b).		N/A
7.3.6.3.5	External protective earthing conductor		N/A
	A protective earthing conductor shall be connected at all times when power is supplied to PCE of protective class I. Unless local wiring regulations state otherwise, the protective earthing conductor cross-sectional area shall be determined from Table 11 or by calculation according to IEC 60364-5-54.		N/A
	If the external protective earthing conductor is routed through a plug and socket or similar means of disconnection, it shall not be possible to disconnect it unless power is simultaneously removed from the part to be protected.		N/A
	The cross-sectional area of every external protective earthing conductor which does not form part of the supply cable or cable enclosure shall, in any case, be not less than:	External protective earthing conductor is integrated with output cable	N/A
	2,5 mm ² if mechanical protection is provided;		N/A
	4 mm ² if mechanical protection is not provided.		N/A
	For cord-connected equipment, provisions shall be made so that the external protective earthing conductor in the cord shall, in the case of failure of the strain-relief mechanism, be the last conductor to be interrupted.		N/A
7.3.6.3.6	Means of connection for the external protective earthing conductor		P
7.3.6.3.6.1	General		P
	The means of connection for the external protective earthing conductor shall be located near the terminals for the respective live conductors. The means of connections shall be corrosion-resistant and shall be suitable for the connection of cables according to 7.3.6.3.5.		P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	<p>The means of connection for the protective earthing conductor shall not be used as a part of the mechanical assembly of the equipment or for other connections.</p> <p>A separate means of connection shall be provided for each external protective earthing conductor.</p> <p>Connection and bonding points shall be so designed that their current-carrying capacity is not impaired by mechanical, chemical, or electrochemical influences. Where enclosures and/or conductors of aluminium or aluminium alloys are used, particular attention should be given to the problems of electrolytic corrosion.</p>		
	The means of connection for the protective earthing conductor shall be permanently marked with:		P
	symbol 7 of Annex C; or		N/A
	the colour coding green-yellow		P
	Marking shall not be done on easily changeable parts such as screws.		N/A
7.3.6.3.7	Touch current in case of failure of the protective earthing conductor		P
	The requirements of this sub-clause shall be satisfied to maintain safety in case of damage to or disconnection of the protective earthing conductor.		P
	For pluggable equipment type A, the touch current measured in accordance with 7.5.4 shall not exceed 3,5 mA a.c. or mA d.c.		N/A
	For all other PCE, one or more of the following measure shall be applied, unless the touch current measured in accordance with 7.5.4 using the test network of IEC 60990 test figure 4 shall not exceed 3,5 mA a.c. or 10 mA d.c.		P
	a) Permanently connected wiring, and:	Not exceed 3,5 mA a.c.	N/A
	a cross-section of the protective earthing conductor of at least 10 mm ² Cu or 16 mm ² Al; or		N/A
	automatic disconnection of the supply in case of discontinuity of the protective earthing conductor; or		N/A
	provision of an additional terminal for a second protective earthing conductor of the same cross-sectional area as the original protective earthing conductor and installation instruction requiring a second protective earthing conductor to be installed or		N/A

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	b) Connection with an industrial connector according to IEC 60309 and a minimum protective earthing conductor cross-section of 2,5 mm ² as part of a multi-conductor power cable. Adequate strain relief shall be provided.		N/A
	In addition, the caution symbol 15 of Annex C shall be fixed to the product and the installation manual shall provide details of the protective earthing measures required in the installation as required in 5.3.2.		N/A
	When it is intended and allowed to connect two or more PCEs in parallel using one common PE conductor, the above touch current requirements apply to the maximum number of the PCEs to be connected in parallel, unless one of the measures in a)		N/A
	or b) above is used. The maximum number of parallel PCEs is used in the testing and has to be stated in the installation manual.		N/A
7.3.6.4	Protective Class II – Double or Reinforced Insulation	Communication interface is evaluated with Reinforced insulation from live part inside. Comply with clause 7.3.4.3	P
	Equipment or parts of equipment designed for protective class II shall have insulation between live parts and accessible surfaces in accordance with 7.3.4.3. The following requirements also apply:		N/A
	equipment designed to protective class II shall not have means of connection for the external protective earthing conductor. However this does not apply if the external protective earthing conductor is passed through the equipment to equipment series-connected beyond it. In the latter event, the external protective earthing conductor and its means for connection shall be insulated with basic insulation from the accessible surface of the equipment and from circuits that employ protective separation, extra-low voltage, protective impedance and limited discharging energy, according to 7.3.5. This basic insulation shall correspond to the rated voltage of the series-connected equipment;		N/A
	metal-encased equipment of protective class II may have provision on its enclosure for the connection of an equipotential bonding conductor;		N/A
	equipment of protective class II may have provision for the connection of an earthing conductor for functional reasons or for damping of		N/A

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	overvoltages; it shall, however, be insulated as though it is a live part;		
	equipment employing protective class II shall be marked according to 5.1.8.		N/A
7.3.7	Insulation Including Clearance and Creepage Distance		P
7.3.7.1	General		P
	This subclause gives minimum requirements for insulation, based on the principles of IEC 60664.		P
	Manufacturing tolerances shall be taken into account during measurement of creepage, clearance, and insulation distance in the PCE.		P
	Insulation shall be selected after consideration of the following influences:		P
	pollution degree	PD2	P
	overvoltage category	PV (OVC II), Mains (OVC II)	P
	supply earthing system	TN	P
	insulation voltage	PV input: max. 430 Vd.c. and Mains: 230 Va.c.	P
	location of insulation	See table 7.3.7.4 and 7.3.7.5 for detail	P
	type of insulation	See table 7.3.7.4 and 7.3.7.5 for detail	P
	Compliance of insulation, creepage distances, and clearance distances, shall be verified by measurement or visual inspection, and the tests of 7.5.		P
7.3.7.1.3	Supply earthing systems		P
	Three basic types of earthing system are described in IEC 60364-1. They are:	Inverter is intended to installed in TN system	P
	TN system: has one point directly earthed, the accessible conductive parts of the installation being connected to that point by protective conductors. Three types of TN systems, TN-C, TN-S and TN-C-S, are defined according to the arrangement of the neutral and protective conductor.		P
	TT system: has one point directly earthed, the accessible conductive parts of the installation being connected to earth electrodes electrically independent of the earth electrodes of the power system;		N/A

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	IT sytem: has all live parts isolated from earth or one point connected to earth through an impedance, the accessible conductive parts of the installation being earthed independently or collectively to the earthing system.		N/A
7.3.7.1.4	Insulation voltages	See table 7.3.7.4 and 7.3.7.5 for detail	P
	Table 12 makes use of the circuit system voltage and overvoltage category to define the impulse withstand voltage and the temporary overvoltage.		P
7.3.7.2	Insulation between a circuit and its surroundings		P
7.3.7.2.1	General	230V, OVC II (4000 V impulse voltage, 1500 Vrms temporary overvoltage) for the AC ouput terminal and 430V, OVC II (4000V impulse voltage, no temporary overvoltage) for the PV input terminal No isolation between PV and AC mains output. Maximum 230V rms working voltage is assumed between DVC A circuit and DVC C circuit.	P
7.3.7.2.2	Circuits connected directly to the mains	System voltage for mains is 230Vrms according to table 12. 2500 V impulse voltage gives the most severe requirement	P
7.3.7.2.3	Circuits other than mains circuits	System voltage for PV is 430Vdc	P
7.3.7.2.4	Insulation between circuits	Impulse voltage (4000 V), temporary overvoltage (1500 Vr.m.s) is calculated from table 12 for clearance. Working voltage (230Vdc) across insulation is used for creepage	P
7.3.7.3	Functional insulating		P
7.3.7.4	Clearance distances		P
7.3.7.4.1	Determination		P
7.3.7.4.2	Electric field homogeneity	Inhomogeneous electric field is considered for PCE	N/A
7.3.7.4.3	Clearance to conductive enclosures		P
7.3.7.5	Creepage distances		P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
7.3.7.5.1	General	PV Maximum 450V system voltage is used for the RMS voltage across insulation	P
7.3.7.5.2	Voltage		P
7.3.7.5.3	Materials	Certified PWB used. Other material are considered IIIb The inside parts are considered pollution degree 2	P
7.3.7.6	Coating	No coating provided insulation	N/A
7.3.7.7	PWB spacings for functional insulating	PWB rated V-0 and has a minimum CTI of 175, short-circuit test are considered	P
7.3.7.8	Solid insulating		P
7.3.7.8.1	General	Optical Isolator and transformer	P
7.3.7.8.2	Requirements for electrical withstand capability of solid insulation		P
7.3.7.8.2.1	Basic, supplemental, reinforced, and double insulation		P
7.3.7.8.2.2	Functional insulation		N/A
7.3.7.8.3	Thin sheet or tape material		P
7.3.7.8.3.1	General		P
7.3.7.8.3.2	Material thickness not less than 0,2 mm		P
7.3.7.8.3.3	Material thickness less than 0,2 mm		N/A
7.3.7.8.3.4	Compliance		P
7.3.7.8.4	Printed wiring boards		P
7.3.7.8.4.1	General		P
7.3.7.8.4.2	Use of coating materials		N/A
7.3.7.8.5	Wound components		P
7.3.7.8.6	Potting materials		N/A
7.3.7.9	Insulation requirements above 30 kHz		P
7.3.8	Residual Current-operated protective (RCD) or monitoring (RCM) device compatibility	Internal RCD is used.	P
	RCD and RCM are used to provide protection against insulation faults in some domestic and industrial installations, additional to that provided by the installed equipment.		N/A
7.3.9	Capacitor discharge		P
7.3.9.1	Operator access area	Internal RCD is used.	P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Equipment shall be so designed that there is no risk of electric shock in operator access areas from charge stored on capacitors after disconnection of the PCE.		P
7.3.9.2	Service access areas		P
	Capacitors located behind panels that are removable for servicing, installation, or disconnection shall present no risk of electric shock or energy hazard from charge stored on capacitors after disconnection of the PCE.		P
7.4	Protection against energy hazards		P
7.4.1	Determination of hazardous energy level		P
	A hazardous energy level is considered to exist if	Condition b is considered	P
	The voltage is 2 V or more, and power available after 60 s exceeds 240 VA.		N/A
	The stored energy in a capacitor is at a voltage. U of 2 V or more, and the stored energy. E, calculated from the following equation, exceeds 20J: $E = 0,5 CU^2$	See below Cl.7.4.3	P
7.4.2	Operator Access Areas	No energized parts accessible by user	P
	Equipment shall be so designed that there is no risk of energy hazard in operator access areas from accessible circuits.		P
7.4.3	Services Access Areas		P
7.5	Electrical tests related to shock hazard		P
7.5.1	Impulse voltage test (type test)		P
7.5.2	Voltage test (dielectric strength test)		P
7.5.2.1	Purpose of test		P
7.5.2.2	Value and type of test voltage		P
7.5.2.3	Humidity pre-conditioning		P
7.5.2.4	Performing the voltage test		P
7.5.2.5	Duration of the a.c. or d.c. voltage test		P
7.5.2.6	Verification of the a.c. or d.c. voltage test		P
7.5.3	Partial discharge test		P
7.5.4	Touch current measurement (type test)		P
	The touch current shall be measured if required by 7.3.6.3.7 and shall not be greater than 3.5 mA a.c. or 10 mA d.c. or special measures of protection as given in 7.3.6.3.7 are required.	Measured touch current is 1.38mA	P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	For type tests on PCE for which wet locations requirements apply according to 6.1, the humidity pre-conditioning of 4.5 shall be performed immediately prior to the touch current test.		P
7.5.5	Equipment with multiple sources of supply		N/A
8	PROTECTION AGAINST MECHANICAL HAZARDS		P
8.1	General		P
	Operation shall not lead to a mechanical HAZARD in NORMAL CONDITION or SINGLE FAULT CONDITION. Edges, projections, corners, openings, guards, handles and the like, that are accessible to the operator shall be smooth and rounded so as not to cause injury during normal use of the equipment.		P
	Conformity is checked as specified in 8.2 to 8.6.		P
8.2	Moving parts		P
	Moving parts shall not be able to crush, cut or pierce parts of the body of an OPERATOR likely to contact them, nor severely pinch the OPERATOR's skin. Hazardous moving parts of equipment, that is moving parts which have the potential to cause injury, shall be so arranged, enclosed or guarded as to provide adequate protection against the risk of personal injury.	Moving part can not touched	P
8.2.1	Protection of service persons		P
	Protection shall be provided such that unintentional contact with hazardous moving parts is unlikely during servicing operations. If a guard over a hazardous moving part may need to be removed for servicing, the marking of symbol 15 of Table D-1 shall be applied on or near the guard.		P
8.3	Stability		N/A
	Equipment and assemblies of equipment not secured to the building structure before operation shall be physically stable in NORMAL USE.		N/A
8.4	Provisions for lifting and carrying		P
	If carrying handles or grips are fitted to, or supplied with, the equipment, they shall be capable of withstanding a force of four times the weight of the equipment.		P
	Equipment or parts having a mass of 18 kg or more shall be provided with a means for lifting and carrying or directions shall be given in the manufacturer's documentation.		P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
8.5	Wall mounting		N/A
	Mounting brackets on equipment intended to be mounted on a wall or ceiling shall withstand a force of four times the weight of the equipment.		N/A
8.6	Expelled parts		N/A
	Equipment shall contain or limit the energy of parts that could cause a HAZARD if expelled in the event of a fault.		N/A
9	PROTECTION AGAINST FIRE HAZARDS		P
9.1	Resistance to fire		P
	This subclause specifies requirements intended to reduce the risk of ignition and the spread of flame, both within the equipment and to the outside, by the appropriate use of materials and components and by suitable construction.	Components are witnessed at normal condition and abnormal tests are verified	P
9.1.1	Reducing the risk of ignition and spread of flame		P
	For equipment or a portion of equipment, there are two alternative methods of providing protection against ignition and spread of flame that could affect materials, wiring, wound components and electronic components such as integrated circuits, transistors, thyristors, diodes, resistors and capacitors.	Method 1 used	P
9.1.2	Conditions for a fire enclosure		P
	A FIRE ENCLOSURE is required for equipment or parts of equipment for which Method 2 is not fully applied and complied with.		P
9.1.2.1	Parts requiring a fire enclosure		P
	Except where Method 2 is used, or as permitted in 9.1.2.2, the following are considered to have a risk of ignition and, therefore, require a FIRE ENCLOSURE:		P
	components in PRIMARY CIRCUITS		P
	components in SECONDARY CIRCUITS supplied by power sources which exceed the limits for a LIMITED POWER SOURCE as specified in 9.2;		P
	components in SECONDARY CIRCUITS supplied by a LIMITED POWER SOURCE as specified in 9.2, but not mounted on a material of FLAMMABILITY CLASS V-1;		N/A
	components within a power supply unit or assembly having a limited power output complying with the criteria for a LIMITED POWER SOURCE as specified in 9.2, including overcurrent protective devices, limiting impedances, regulating networks and wiring, up		P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	to the point where the LIMITED POWER SOURCE output criteria are met;		
	components having unenclosed arcing parts, such as open switch and relay contacts and commutators, in a circuit at HAZARDOUS VOLTAGE or at a HAZARDOUS ENERGY LEVEL; and		N/A
	insulated wiring, except as permitted in 9.1.2.2.	PVC wire	N/A
9.1.2.2	Parts not requiring a fire enclosure	Fire enclosure used	N/A
9.1.3	Materials requirements for protection against fire hazard		P
9.1.3.1	General		P
	ENCLOSURES, components and other parts shall be so constructed, or shall make use of such materials, that the propagation of fire is limited.		P
9.1.3.2	Materials for fire enclosures		P
	If an enclosure material is not classified as specified below, a test may be performed on the final enclosure or part of the enclosure, in which case the material shall additionally be subjected to periodic SAMPLE testing.		P
9.1.3.3	Materials for components and other parts outside fire enclosures	At least V-1 material used inside fire enclosure, PCB rated V-0 and internal wire rated VW-1	P
	Except as otherwise noted below, materials for components and other parts (including MECHANICAL ENCLOSURES, ELECTRICAL ENCLOSURES and DECORATIVE PARTS); located outside FIRE ENCLOSURES, shall be of FLAMMABILITY CLASS HB.		N/A
9.1.3.4	Materials for components and other parts inside fire enclosures		N/A
9.1.3.5	Materials for air filter assemblies		N/A
9.1.4	Openings in fire enclosures		P
9.1.4.1	General		P
	For equipment that is intended to be used or installed in more than one orientation as specified in the product documentation, the following requirements apply in each orientation.		P
	These requirements are in addition to those in the following sections:		P
	7.3.4, Protection against direct contact;		P
	7.4, Protection against energy hazards;		P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	13.5, Openings in enclosures		P
9.1.4.2	Side openings treated as bottom openings	Side openings	P
9.1.4.3	Openings in the bottom of a fire enclosure		P
	The bottom of a FIRE ENCLOSURE or individual barriers, shall provide protection against emission of flaming or molten material under all internal parts, including partially enclosed components or assemblies, for which Method 2 of 9.1.1 has not been fully applied and complied with.		P
9.1.4.4	Equipment for use in a CLOSED ELECTRICAL OPERATING AREA	Not intend use at this area	N/A
	The requirements of 9.1.4.3 do not apply to FIXED EQUIPMENT intended only for use in a CLOSED ELECTRICAL OPERATING AREA and to be mounted on a concrete floor or other non-combustible surface. Such equipment shall be marked as follows:		N/A
	WARNING: FIRE HAZARD SUITABLE FOR MOUNTING ON CONCRETE OR OTHER NON-COMBUSTIBLE SURFACE ONLY		N/A
9.1.4.5	Doors or covers in fire enclosures	No door or cover operated by user	N/A
9.1.4.6	Additional requirements for openings in transportable equipment		N/A
9.2	LIMITED POWER SOURCES		N/A
9.2.1	General		N/A
9.2.2	Limited power source tests		N/A
9.3	Short-circuit and overcurrent protection		P
9.3.1	General		P
	The PCE shall not present a hazard, under short-circuit or overcurrent conditions at any port, including phase-to-phase, phase-to-earth and phase-to-neutral, and adequate information shall be provided to allow proper selection of external wiring and external protective devices.		P
9.3.2	Protection against short-circuits and overcurrents shall be provided for all input circuits, and for output circuits that do not comply with the requirements for limited power sources in 9.2, except for circuits in which no overcurrent hazard is presented by short-circuits and overloads.		P
9.3.3	Protective devices provided or specified shall have adequate breaking capacity to interrupt the maximum short circuit current specified for the port to which they are connected. If protection that is provided integral to the PCE for an input port is		N/A

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	not rated for the short-circuit current of the circuit in which it is used, the installation instructions shall specify that an upstream protective device, rated for the prospective short-circuit current of that port, shall be used to provide backup protection.		
10	PROTECTION AGAINST SONIC PRESSURE HAZARDS		P
10.1	General		P
	The equipment shall provide protection against the effect of sonic pressure. Conformity tests are carried out if the equipment is likely to cause such HAZARDS.	< 60 dBA	P
10.2	Sonic pressure and Sound level		N/A
10.2.1	Hazardous Noise Levels		N/A
11	PROTECTION AGAINST LIQUID HAZARDS		N/A
11.1	Liquid Containment, Pressure and Leakage	Indoor used	N/A
	The liquid containment system components shall be compatible with the liquid to be used.		N/A
	There shall be no leakage of liquid onto live parts as a result of:		N/A
	Normal operation, including condensation;		N/A
	Servicing of the equipment; or		N/A
	Inadvertent loosening or detachment of hoses or other cooling system parts over time.		N/A
11.2	Fluid pressure and leakage		N/A
11.2.1	Maximum pressure		N/A
11.2.2	Leakage from parts		N/A
11.2.3	Overpressure safety device		N/A
11.3	Oil and grease		N/A
12	CHEMICAL HAZARDS		N/A
12.1	General		N/A
13	PHYSICAL REQUIREMENTS		P
13.1	Handles and manual controls		N/A
	Handles, knobs, grips, levers and the like shall be reliably fixed so that they will not work loose in normal use, if this might result in a hazard. Sealing compounds and the like, other than self-hardening resins, shall not be used to prevent loosening. If handles, knobs and the like are used to indicate the position of switches or similar components, it shall not be possible to fix them in		N/A

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	a wrong position if this might result in hazard.		
13.1.1	Adjustable controls		N/A
13.2	Securing of parts		P
13.3	Provisions for external connections		P
13.3.1	General		P
13.3.2	Connection to an a.c. Mains supply		P
13.3.2.1	General	Certified PV and AC connectors are used. Installation manual provide information for the disconnection means	P
	For safe and reliable connection to a MAINS supply, equipment shall be provided with one of the following:		P
	terminals or leads or a non-detachable power supply cord for permanent connection to the supply; or		P
	a non-detachable power supply cord for connection to the supply by means of a plug		N/A
	an appliance inlet for connection of a detachable power supply cord; or		N/A
	a mains plug that is part of direct plug-in equipment as in 13.3.8		N/A
13.3.2.2	Permanently connected equipment		P
13.3.2.3	Appliance inlets		N/A
13.3.2.4	Power supply cord		N/A
13.3.2.5	Cord anchorages and strain relief	Certified male and female connector used	N/A
	For equipment with a non-detachable power supply cord, a cord anchorage shall be supplied such that:		N/A
	the connecting points of the cord conductors are relieved from strain; and		N/A
	the outer covering of the cord is protected from abrasion.		N/A
13.3.2.6	Protection against mechanical damage		N/A
13.3.3	Wiring terminals for connection of external conductors		P
13.3.3.1	Wiring terminals		P
13.3.3.2	Screw terminals		P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
13.3.3.3	Wiring terminal sizes		P
13.3.3.4	Wiring terminal design		P
13.3.3.5	Grouping of wiring terminals		P
13.3.3.6	Stranded wire		P
13.3.4	Supply wiring space		N/A
13.3.5	Wire bending space for wires 10 mm ² and greater		N/A
13.3.6	Disconnection from supply sources	Installation manual instruct the disconnect device shall be provided before connecting AC mains and PV array	P
13.3.7	Connectors, plugs and sockets		N/A
13.3.8	Direct plug-in equipment		N/A
13.4	Internal wiring and connections		P
13.4.1	General		P
13.4.2	Routing	Internal wire is routed to avoid sharp edge and overheat	P
13.4.3	Colour coding	Green-yellow wire used as protective bonding only	P
13.4.4	Splices and connections		P
13.4.5	Interconnections between parts of the PCE		N/A
13.5	Openings in enclosures		P
13.5.1	Top and side openings		P
	Openings in the top and sides of ENCLOSURES shall be so located or constructed that it is unlikely that objects will enter the openings and create hazards by contacting bare conductive parts.		P
13.6	Polymeric Materials		P
13.6.1	General		P
13.6.1.1	Thermal index or capability		P
13.6.2	Polymers serving as enclosures or barriers preventing access to hazards	Polymers serving as barriers preventing access to hazards	P
13.6.2.1	Stress relief test	For top enclosure and LCD cover	P
13.6.3	Polymers serving as solid insulation		P
13.6.3.1	Resistance to arcing		N/A
13.6.4	UV resistance		N/A
	Polymeric parts of an OUTDOOR ENCLOSURE	Indoor used	N/A

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	required for compliance with this standard shall be sufficiently resistance to degradation by ultra-violet (UV) radiation		
13.7	Mechanical resistance to deflection, impact, or drop		P
13.7.1	General		P
13.7.2	250-N deflection test for metal enclosures		P
13.7.3	7-J impact test for polymeric enclosures	Top enclosure, fan guard and LED cover are all tested at lowest temperature 0°C	P
13.7.4	Drop test		N/A
13.8	Thickness requirements for metal enclosures		P
13.8.1	General		P
13.8.2	Cast metal	Thickness >2,5 mm	P
13.8.3	Sheet metal		N/A
14	COMPONENTS		P
14.1	General		P
	Where safety is involved, components shall be used in accordance with their specified RATINGS unless a specific exception is made. They shall conform to one of the following:		P
	applicable safety requirements of a relevant IEC standard. Conformity with other requirements of the component standard is not required. If necessary for the application, components shall be subjected to the test of this standard, except that it is not necessary to carry out identical or equivalent tests already performed to check conformity with the component standard;		P
	the requirements of this standard and, where necessary for the application, any additional applicable safety requirements of the relevant IEC component standard;		P
	if there is no relevant IEC standard, the requirements of this standard;		P
	applicable safety requirements of a non-IEC standard which are at least as high as those of the applicable IEC standard, provided that the component has been approved to the non-IEC standard by a recognized testing authority.		P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Components such as optocouplers, capacitors, transformers, and relays connected across basic, supplemental, reinforced, or double insulation shall comply with the requirements applicable for the grade of insulation being bridged, and if not previously certified to the applicable component safety standard shall be subjected to the voltage test of 7.5.2 as routine test.		P
14.2	Motor Over temperature Protection		P
	Motors which, when stopped or prevented from starting (see 4.4.4.3), would present an electric shock HAZARD, a temperature HAZARD, or a fire HAZARD, shall be protected by an over temperature or thermal protection device meeting the requirements of 14.3.		P
14.3	Over temperature protection devices		N/A
14.4	Fuse holders		N/A
14.5	MAINS voltage selecting devices		N/A
14.6	Printed circuit boards		P
	Printed circuit boards shall be made of material with a flammability classification of V-1 of IEC 60707 or better.	V-0	P
	This requirement does not apply to thin-film flexible printed circuit boards that contain only circuits powered from limited power sources meeting the requirements of 9.2.		N/A
	Conformity of the flammability RATING is checked by inspection of data on the materials. Alternatively, conformity is checked by performing the V-1 tests specified in IEC 60707 on three samples of the relevant parts.		N/A
14.7	Circuits or components used as transient overvoltage limiting devices		P
	If control of transient overvoltage is employed in the equipment, any overvoltage limiting component or circuit shall be tested with the applicable impulse withstand voltage of Table 7-10 using the test method from 7.5.1 except 10 positive and 10 negative impulses are to be applied and may be spaced up to 1 min apart.		P
14.8	Batteries		N/A
	Equipment containing batteries shall be designed to reduce the risk of fire, explosion and chemical leaks under normal conditions and after a single fault in the equipment including a fault in circuitry within the equipment battery pack.		N/A
14.8.1	Battery Enclosure Ventilation		N/A

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict
14.8.1.1	Ventilation requirements		N/A
14.8.1.2	Ventilation testing		N/A
14.8.1.3	Ventilation instructions		N/A
14.8.2	Battery Mounting		N/A
	Compliance is verified by the application of the force to the battery's mounting surface. The test force is to be increased gradually so as to reach the required value in 5 to 10 s, and is to be maintained at that value for 1 min. A non-metallic rack or tray shall be tested at the highest normal condition operating temperature.		N/A
14.8.3	Electrolyte spillage		N/A
	Battery trays and cabinets shall have an electrolyte-resistant coating.		N/A
	The ENCLOSURE or compartment housing a VENTED BATTERY shall be constructed so that spillage or leakage of the electrolyte from one battery will be contained within the ENCLOSURE and be prevented from:		N/A
	reaching the PCE outer surfaces that can be contacted by the USER		N/A
	contaminating adjacent electrical components or materials; and		N/A
	bridging required electrical distances		N/A
14.8.4	Battery Connections		N/A
	Reverse battery connection of the terminals shall be prevented if reverse connection could result in a hazard within the meaning of this Standard		N/A
14.8.5	Battery maintenance instructions		N/A
	The information and instructions listed in 5.3.4.1 shall be included in the operator manual for equipment in which battery maintenance is performed by the operator, or in the service manual if battery maintenance is to be performed by service personnel only.		N/A
14.8.6	Battery accessibility and maintainability		N/A
	Battery terminals and connectors shall be accessible for maintenance with the correct TOOLS. Batteries with liquid electrolyte, requiring maintained shall be so located that the battery cell caps are accessible for electrolyte tests and readjusting of electrolyte levels.		N/A
15	Software and firmware performing safety functions	1.23.06	P

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict

4.2.2.6	TABLE: mains supply electrical data in normal condition					P
Type	U (V) DC	I (A) DC	P (W) DC	U (V) grid	I (A) AC	P (KW) AC
PV18-5548VHM	Off-grid Mode					
	48VDC	115.0	5520	230V	23.94	5506.2
	AC Charge mode					
	207Vac	23.66	4897.2	48VDC	100	4800
	230Vac	21.30	4897.0	48VDC	100	4800
	253Vac	19.36	4897.1	48VDC	100	4800
	PV input mode					
	150VDC	25.6	3820	--	--	--
	430VDC	11.81	5110	--	--	--
--						

4.3	TABLE: heating temperature rise measurements					P	
	test voltage (V) :	A: PV Input: 150Vdc B: PV Input: 430Vdc; C: Input: 48Vdc; Output: 230Vac, max full-load D: Input: 207Vac; Output: 207Vac, max full-load E: Input: 253Vac; Output: 253Vac, max full-load				—	
	t1 (°C):	See below				—	
	t2 (°C) :	See below				—	
Maximum measured temperature T of part/at::		Max. temperature measured(°C)				Max. temperature limit (°C)	
Test Conditions		A	B	C	D	E	--
AC input terminal		52.7	54.8	53.6	61.2	64.0	70
AC input line (L)		54.7	55.4	57.2	65.8	65.7	70
PV input terminal		54.4	55.7	54.3	56.6	58.9	70
PV input line (+)		57.5	58.7	57.9	61.2	61.2	70
U4 Coil		77.4	64.9	62.8	83.9	70.4	130
C56 Body		58.9	63.0	69.0	65.3	69.1	105
TX2 coil		57.9	69.0	56.7	65.3	75.5	110
TX2 core		57.7	68.7	55.2	65.5	74.8	110
PCB near Q2		76.7	65.7	65.2	81.8	70.0	130
REC1 body		55.0	62.1	53.8	61.1	67.6	105

IEC/EN 62109-1							
Clause	Requirement – Test					Result - Remark	Verdict
L2 coil	54.6	60.3	54.4	58.9	64.4	130	
P2P3 coil	96.5	67.9	52	104.7	105.3	130	
PCB near BAT+	67.4	73.5	91.6	73.5	78.9	130	
TX5 coil	55.6	58.2	64.7	60.0	62.3	110	
TX5 core	55.3	58	62.7	60.2	61.5	110	
C8 body	70.4	76.4	102.3	79.2	84.9	105	
TX1 coil	73.1	79.5	99.3	80.9	86.7	110	
TX1 core	83.4	87.8	91.2	90.3	94.2	110	
L1 coil	62.5	64.2	76.2	67.4	69.4	130	
C41 body	60.1	65.3	61.9	66.0	71.2	105	
PCB near Q38	70.2	73	74.6	77.6	80.1	130	
TX9 coil	72.9	71.7	73.8	79.0	78.0	110	
TX9 core	70.2	68.4	69.5	76.8	74.4	110	
RY1 Body	53.8	57.1	59	58.3	60.5	85	
PCB near C143	56.5	64.4	72.7	62.5	69.4	130	
MOV Body	52.7	57.8	60.9	58.0	61.9	85	
C33 Body	52.5	56.2	55.7	57.6	59.5	105	
L4 Coil	52.2	60.1	76.3	57.9	64.0	130	
TX7 coil	52.0	54.8	55.9	57.1	59.4	110	
TX7 core	52.1	55.0	56.2	56.3	59.2	110	
AC output terminal	53.8	53.6	57.4	58.6	57.1	70	
AC output line (L)	54.3	55.2	59.4	59.0	58.9	70	
Fan	56.5	58.7	57.6	61.1	62.7	REF	
metal enclosure	52.0	54.1	53.0	56.9	58.1	60	
LCD	55.2	55.4	54.3	59.8	59.1	65	
Ambient	50.0	50.0	50.0	50.0	50.0	--	
Supplementary information:							
	TABLE: Heating test, resistance method						--
	Test voltage (V)..... :					--	—
	Ambient, t₁ (°C)					--	—
	Ambient, t₂ (°C)					--	—
Temperature rise of winding	R₁ (Ω)	R₂ (Ω)	ΔT (K)	Max. dT (K)	Insulation class		
--	--	--	--	--	--		
Supplementary information:							

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict

4.4		TABLE: fault condition tests					P
		Ambient temperature (°C)				See below.	—
No.	Component no.	Fault	Test voltage (V)	Test time	Fuse no.	Fuse current (A)	Result
1	C8	S-C	48VDC/230VAC	10min	--	0	Unit shutdown immediately, F3 are damage, no hazards
2	C41	S-C	48VDC/230VAC	10min	--	0	Unit shutdown immediately, F3 are damage, no hazards
3	Q14(Pin D-S)	S-C	48VDC/230VAC	10min	--	0	Unit shutdown immediately, F3 are damage, no hazards
4	Q14(Pin D-G)	S-C	48VDC/230VAC	10min	--	0	Unit shutdown immediately, F3 are damage, no hazards
5	Q14(Pin S-G)	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown immediately, no damage, no hazards
6	Q16(Pin S-D)	S-C	48VDC/230VAC	10min	--	0	Unit shutdown immediately, F3 are damage, no hazards
7	Q16(Pin G-D)	S-C	48VDC/230VAC	10min	--	0	Unit shutdown immediately, F3 are damage, no hazards
8	Q16(Pin S-G)	S-C	48VDC/230VAC	10min	--	1.26	Unit shutdown immediately, no damage, no hazards
9	Q15(Pin S-D)	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown immediately, F3 are damage, no hazards

IEC/EN 62109-1							
Clause	Requirement – Test				Result - Remark		Verdict
10	Q15(Pin G-D)	S-C	48VDC/230VAC	10min	--	0	Unit shutdown immediately, F3 are damage, no hazards
11	Q153(Pin G-S)	S-C	48VDC/230VAC	10min	0.2	1.26	Normal operation, no damage, no hazards
12	U1 Pin 1-2	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
13	U1 Pin 3-4	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
14	U1 Pin 1	O-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
15	U1 Pin 3	O-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
16	U2 Pin 1-2	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
17	U2 Pin 3-4	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
18	U2 Pin 1	O-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
19	U2 Pin 3	O-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
20	U3 Pin 1-2	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
21	U3 Pin 3-4	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
22	U3 Pin 1	O-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
23	U3 Pin 3	O-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards

IEC/EN 62109-1							
Clause	Requirement – Test				Result - Remark		Verdict
24	U4 Pin 1-2	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
25	U4 Pin 3-4	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
26	U4 Pin 1	O-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
27	U4 Pin 3	O-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
28	U14 Pin 1-2	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
29	U14 Pin 3-4	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
30	U14 Pin 1	O-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
31	U14 Pin 3	O-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
32	U17 Pin 1-2	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
33	U17 Pin 3-4	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
34	U17 Pin 1	O-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
35	U17 Pin 3	O-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
36	U19 Pin 1-2	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
37	U19 Pin 3-4	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
38	U19 Pin 1	O-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards

IEC/EN 62109-1							
Clause	Requirement – Test				Result - Remark	Verdict	
39	U19 Pin 3	O-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
40	TX9 pin1 - pin 3	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
41	TX9 pin12 - pin 9	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
42	TX9 pin11 - pin 8	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
43	TX9 pin11 - pin 9	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
44	TX9 pin11 - pin 12	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
45	TX9 pin 5 - pin 6	O-C	48VDC/230VAC	10min	--	0.26	Unit shutdown, no damage, no hazards
46	Output L - N	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
47	Battery +/-	S-C	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
48	opening	blocked	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
49	Fan	blocked	48VDC/230VAC	10min	--	0.2	Unit shutdown, no damage, no hazards
Supplementary information: S-C=short-circuited, O-C=open-circuited, O-L=overload.							

7.3.7	TABLE: clearance and creepage distance measurements						P
clearance cl and creepage distance dcr at / of:	Up (V)	U r.m.s. (V)	U impulse (V)	required cl (mm)	cl (mm)	required dcr (mm)	dcr (mm)
Between hazard live parts and earthed terminal on main PCB top layer, (BI)	430	430Vdc 230Vac	2500	3.0	4.1	3.0	4.1
Between hazard live parts and earthed terminal on main PCB bottom layer,	430	430Vdc 430Vac	2500	3.0	4.2	3.0	4.2

IEC/EN 62109-1			
Clause	Requirement – Test	Result - Remark	Verdict

7.3.7	TABLE: clearance and creepage distance measurements						P
clearance cl and creepage distance dcr at / of:	Up (V)	U r.m.s. (V)	U impulse (V)	required cl (mm)	cl (mm)	required dcr (mm)	dcr (mm)
(BI)							
Between hazard live parts and earthed terminal on display PCB top layer, (BI)	430	430Vdc 230Vac	2500	3.0	5.0	3.0	5.0
Between hazard live parts and earthed terminal on display PCB bottom layer, (BI)	430	430Vdc 230Vac	2500	3.0	5.2	3.0	5,2
Supplementary information:							
1. For PV circuit, system voltage is 430V and overvoltage category is OVC II, impulse voltage correspond to PV circuit is 4000V							
2. For AC mains circuit, nominal voltage is 230V and overvoltage category is OVC II, impulse voltage correspond to mains circuit is 2500V							
3. For insulations between live parts, which PV circuit and mains circuit is not isolated, PV system voltage 24V is considered for the maximum working voltage;							

7.3.7.8.3.2 to 7.3.7.8.3.3	TABLE: distance through insulation measurement				N/A
distance through insulation di at/of:	U r.m.s. (V)	test voltage (V)	required di (mm)	di (mm)	

7.5	TABLE: electric strength measurements, impulse voltage test and partial discharge test			P
test voltage applied between:	test voltage (V)	impulse withstand voltage (V)	partial discharge extinction voltage (V)	result
PV terminal and PE	1500Vac	4000V	N/A	No breakdown
AC mains terminal and PE	1500Vac	4000V	N/A	No breakdown
AC mains terminal and DC output	3000Vac	4000V	N/A	No breakdown

14	TABLE: list of critical components					P
object/part No.	manufacturer/trademark	type/model	technical data	standard	mark(s) of conformity ¹⁾	
Metal enclosure	--	--	min. thickness: 1.5mm	--	Test in appliance	

IEC/EN 62109-1					
Clause	Requirement – Test			Result - Remark	Verdict
DC terminal blocks	SHENZHEN SUCCEED ELECTRONICS TECHNOLOGY CO., LTD.	TR-16N-01-2P-BK	600V, 85A	UL 1059	UL E332956
(Alternate)	Shen zhen DEKS Electron Co.,Ltd.	DW16-02-05D	600V, 85A	UL 1059	UL E513356
(Alternate)	Forany Electronic Technology Co.,Ltd	PW22-02	600V, 85A	UL 1059	UL E494725
AC terminal blocks	SHENZHEN SUCCEED ELECTRONICS TECHNOLOGY CO., LTD.	TR-6N-5P	600V, 50A	---	---
(Alternate)	Shen zhen DEKS Electron Co.,Ltd.	DW8-05-V	600V, 50A	UL1059	UL E494725
Power Switch	Light Country CO., LTD.	R19(A)	250V, 10A	UL1054	UL E244250
Circuit breaker	TOPSTONE CORP	breaker	125/250Vac, 40A	EN 60934:2001	TUV R 50015444
DC Fan	Shenzhen Huaxia Hengtai Electronic Co.,Ltd	DA0825B12UH	DC12V, 0.5A	UL 507 EN60950-1	UL E254715 TUV R50229698
Internal wiring	YONG HAO ELECTRICAL INDUSTRY CO LTD	1015	10AWG, 105°C	UL758	UL E240426
For main power board (250-00565-02)					
X-Cap (C54, C72, C73, C150, C151)	FARAD ELECTRONICS CO., LTD	PXK	Max. 0.22uF, min. 250Vac, min. 100°C	IEC 60384-14	VDE UL E247953
(Alternate)	Interchangeable	Interchangeable	Max. 0.22uF, min. 250Vac, min. 100°C	IEC 60384-14	VDE UL E247953
Y-Cap (C70, C71, C119, C120, C121, C122)	Nanjing Yuyue Electronics co, ltd	CT7	Max. 10000pF, min. 250Vac, min. 85°C	UL, CSA, VDE	E187963、12326
(Alternate)	Interchangeable	Interchangeable	Max. 10000pF, min. 250Vac, min. 85°C	IEC 60384-14	P09211069、E237728

IEC/EN 62109-1					
Clause	Requirement – Test			Result - Remark	Verdict
Relay (RY1, RY2, RY3, RY4)	SHORI CO., LTD	S12H-PAS-12	277Vac,40A	EN 60255-23, EN 61810-1, EN 61810-5, UL508.	UL E88991
(Alternate)	Xiamen Hongfa Electroacoustic Co.,Ltd.	HF-165FD-G/12-HY1STF	277Vac,40A	UL, VDE, CQC	UL E134517 VDE 40043143 CQC15002130956
Varistor (MOV1, MOV2, MOV3, MOV4)	BRIGHTKING (SHENZHEN) CO., LTD	471KD20	300Vac, 385Vdc	EN 61051-1, IEC 61051-2/A1, UL 1449	VDE UL E327997
X-Cap (C58)	FARAD ELECTRONICS CO., LTD	PXK	Max. 0.47uF, min. 250Vac, min. 100°C	IEC 60384-14	VDE UL E247953
(Alternate)	Interchangeable	Interchangeable	Max. 0.47uF, min. 250Vac, min. 100°C	IEC 60384-14	VDE UL E247953
Current transformer (CT1)	SHENZHEN FERROCOIL ELECTRONICS TECHNOLOGY CO.,LTD	240-00143-00	130°C	IEC/EN 62109-1	Test in appliance
(Alternate)	SHENZHEN YAMAXI ELECTRONICS CO., LTD.	2400-200143-0000	130°C	IEC/EN 62109-1	Test in appliance
(Alternate)	Shenzhen Jsy TECHNOLOGY CO., LTD	2400-200143-0000	130°C	IEC/EN 62109-1	Test in appliance
Y-Cap (C59, C60)	Nanjing Yuyue Electronics co.,ltd	CT7	1000pF, min. 250Vac, min. 85°C	UL, CSA, VDE	VDE 40008013, UL E237728
(Alternate)	Interchangeable	Interchangeable	1000pF, min. 250Vac, min. 85°C	--	--
Chock (L2)	POWERTEK ELECTRONIC (SHEN ZHEN) CO., LTD	230-00119-00	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	SHENZHEN BAOYINENG ELECTRON TECHNOLOGY CO., LTD	2300-000119-0000	Class B	IEC/EN 62109-1	Test in appliance

IEC/EN 62109-1					
Clause	Requirement – Test			Result - Remark	Verdict
(Alternate)	SHENZHEN FERROCOIL ELECTRONICS TECHNOLOGY CO., LTD.	2300-000119-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	HUIZHOU INDUCTANCE ELECTRONIC TECHNOLOGY CO., LTD.	2300-000119-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	HONGWEI SHENZHEN CO.,LTD	2300-000119-0000	Class B	IEC/EN 62109-1	Test in appliance
Cap (C33),	Farad Electronics Co.,Ltd	MPC	20UF/350VAC 105°C	-	-
Transformer (TX7)	SHENZHEN YAMAXI ELECTRONIC CO.,LTD	240-00148-00	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	Shenzhen Jsy TECHNOLOGY CO., LTD	2400-000148-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	JEPULS TECHNOLOGY (SHENZHEN) CO., LTD.	2400-000148-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	SHENZHEN CLICK TECHNOLOGY CO., LTD	2400-000148-0000	Class B	IEC/EN 60950-1	Test in appliance
Chock (L4)	POWERTEK ELECTRONIC (SHEN ZHEN) CO.,LTD	230-00087-00	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	HUIZHOU INDUCTANCE ELECTRONIC TECHNOLOGY CO.,LTD.	230-000087-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	SHENZHEN YAMAXI ELECTRONIC CO.,LTD	230-000087-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	SHENZHEN YUYUAN ELECTRIC CO., LTD.	230-000087-0000	Class B	IEC/EN 62109-1	Test in appliance

IEC/EN 62109-1					
Clause	Requirement – Test			Result - Remark	Verdict
E-Cap (C40, C41)	--	--	470uF, 500V, 105°C	--	--
(Alternate)	--	--	470uF, 550V, 105°C	--	--
Transformer (TX9)	SHENZHEN YAMAXI ELECTRONIC CO.,LTD	2400-000149-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	SHENZHEN CLICK TECHNOLOGY CO.,LTD	2400-000149-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	JEPULS TECHNOLOGY (SHENZHEN) CO., LTD.	2400-000149-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	Shenzhen Jsy TECHNOLOGY CO.,LTD	2400-000149-0000	Class B	IEC/EN 62109-1	Test in appliance
--Bobbin	MATERIAL: T375HF 94V-0		V-0, 150°C, Min. 0.51mm thickness	UL 94	UL E59481
--Insulation tape	JINGJIANG YAHUA PRESSURE SENSITIVE GLUE CO LTD	PF	130°C	UL 510	UL E165111
--Margin tape	JINGJIANG YAHUA PRESSURE SENSITIVE GLUE CO LTD	PF	180°C	UL 510	UL E165111
--Magnet wire	GUANGZHOU WANBAO ENAMELLED CO.,LTD OR EQUAL	UEW 130°C	155°C	UL 1446	UL E167402
(Alternate)	TAI-I ELECTRIC WIRE & CABLE CO LTD	UEWF	155°C	UL 1446	UL E85640
--Varnish	HANG CHEUNG PETROCHEMICAL LTD OR EQUAL	8562(a)	155°C	UL 1446	UL E200154

IEC/EN 62109-1					
Clause	Requirement – Test		Result - Remark		Verdict
Opto coupler (U8, U11, U13, U17)	COSMO ELECTRONICS CORP	K1010	Int. CR / Ext. CR / Dti. ≥6,5 mm / ≥6,5mm / >0,4 mm, 55/115/21	IEC 60747-5-2:1997 + A1:2002	VDE 101347 UL E169586
Transformer (TX2)	CLICK	2400-000144-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	SHENZHEN YAMAXI ELECTRONIC CO., LTD	2400-000144-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	JEPULS TECHNOLOGY (SHENZHEN) CO., LTD.	2400-000144-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	Shenzhen Jsy TECHNOLOGY CO., LTD	2400-000144-0000	Class B	IEC/EN 62109-1	Test in appliance
--Bobbin	E I DUPONT DE NEMOURS & CO INC		V-0, 200°C, Min. 0.51mm thickness	UL 94	UL E34739
--Insulation tape	JINGJIANG YAHUA PRESSURE SENSITIVE GLUE CO LTD	PF	180°C	UL 510	UL E165111
--Margin tape	JINGJIANG YAHUA PRESSURE SENSITIVE GLUE CO LTD	PF	180°C	UL 510	UL E165111
--Magnet wire	PACIFIC ELECTRIC WIRE & CABLE (SHENZHEN) CO LTD	PEWF/U, UEWN/U	155°C	UL 1446	UL E201757
(Alternate)	TAI-I ELECTRIC WIRE & CABLE CO LTD	UEWF	155°C	UL 1446	UL E85640
--Tubing	GREAT HOLDING INDUSTRIAL CO LTD	TFL	200°C	UL 224	UL E156256
--Varnish	JOHN C DOLPH CO	BC-346A	Min. 200°C	UL 1446	UL E317427

IEC/EN 62109-1					
Clause	Requirement – Test			Result - Remark	Verdict
(Alternate)	ELANTAS ELECTRICAL INSULATION ELANTAS PDG INC	V1630FS	Min. 155°C	UL 1446	UL E75225
E-Cap (C8, C12, C9, C13)	SHIN KAIMEI ELECTRONIC (SHEN ZHEN) CO.,LTD.	WLC332M1JL4 4RDE	3300uF, 63V, 105°C	--	--
(Alternate)	JIAYE ELECTRONICS CO., LTD	EH1J332M184 5PBGSY	3300uF, 63V, 105°C	--	--
(Alternate)	SAMXON	EGT338M1JL4 0RR	3300uF, 63V, 105°C	--	--
Chock (L1)	POWERTEK ELECTRONIC (SHEN ZHEN) CO., LTD	2400-000086- 0000	Class B	IEC/EN 60950- 1	Test in appliance
(Alternate)	Shenzhen Jsy TECHNOLOGY CO., LTD	2400-000086- 0000	Class B	IEC/EN 60950- 1	Test in appliance
(Alternate)	SHENZHEN YAMAXI ELECTRONIC CO., LTD	2400-000086- 0000	Class B	IEC/EN 60950- 1	Test in appliance
(Alternate)	HONGWEI SHENZHEN CO., LTD	2400-000086- 0000	Class B	IEC/EN 62109- 1	Test in appliance
Transformer (TX1)	SHENZHEN YAMAXI ELECTRONIC CO.,LTD	2400-000145- 0000	Class F(155°C)	IEC/EN 62109- 1	Test in appliance
(Alternate)	Shenzhen Jsy TECHNOLOGY CO.,LTD	2400-000145- 0000	Class F(155°C)	IEC/EN 62109- 1	Test in appliance
(Alternate)	HONGWEI SHENZHEN CO.,LTD	2400-000145- 0000	Class F(155°C)	IEC/EN 62109- 1	Test in appliance
--Insulation tape	JINGJIANG YAHUA PRESSURE SENSITIVE GLUE CO LTD	PF	180°C	UL 510	UL E165111

IEC/EN 62109-1					
Clause	Requirement – Test			Result - Remark	Verdict
--Margin tape	JINGJIANG YAHUA PRESSURE SENSITIVE GLUE CO LTD	PF	180°C	UL 510	UL E165111
--Magnet wire	PACIFIC ELECTRIC WIRE & CABLE (SHENZHEN) CO LTD	PEWF/U, UEWN/U	155°C	UL 1446	UL E201757
(Alternate)	TAI-I ELECTRIC WIRE & CABLE CO LTD	UEWF	155°C	UL 1446	UL E85640
--Tubing	GREAT HOLDING INDUSTRIAL CO LTD	TFL	200°C	UL 224	UL E156256
--Varnish	JOHN C DOLPH CO	BC-346A	Min. 200°C	UL 1446	UL E317427
(Alternate)	ELANTAS ELECTRICAL INSULATION ELANTAS PDG INC	V1630FS	Min. 155°C	UL 1446	UL E75225
Transformer (TX10, TX11)	SHENZHEN YAMAXI ELECTRONIC CO., LTD	2400-000150- 0000	Class B	IEC/EN 60950- 1	Test in appliance
(Alternate)	Shenzhen Jsy TECHNOLOGY CO., LTD	2400-000150- 0000	Class B	IEC/EN 62109- 1	Test in appliance
(Alternate)	JEPULS TECHNOLOGY (SHENZHEN) CO., LTD.	2400-000150- 0000	Class B	IEC/EN 62109- 1	Test in appliance
--Bobbin	CHANG CHUN PLASTICS CO LTD OR EQUAL		V-0, 150°C, Min. 0.51mm thickness	UL 94	UL E59481
--Insulation tape	JINGJIANG YAHUA PRESSURE SENSITIVE GLUE CO LTD	PF	130°C	UL 510	UL E165111
--Margin tape	YUEYANG GREEN TECHNOLIGY CO .,LTD OR EQUAL	PF	130°C	UL 510	UL E165111

IEC/EN 62109-1					
Clause	Requirement – Test	Result - Remark			Verdict
--Magnet wire	GUANGZHOU WANBAO ENAMELLED CO.,LTD OR EQUAL	UEW 130°C	155°C	UL 1446	UL E167402
--Varnish	HANG CHEUNG PETROCHEMICAL LTD OR EQUAL	8562(a)	155°C	UL 1446	UL E200154
--Varnish	JOHN C DOLPH CO	BC-346A	Min. 200°C	UL 1446	UL E317427
Transformer (TX5, TX8)	SHENZHEN YAMAXI ELECTRONIC CO., LTD	2400-000146-0000	Class B	IEC/EN 60950-1	Test in appliance
(Alternate)	Shenzhen Jsy TECHNOLOGY CO., LTD	2400-000146-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	JEPULS TECHNOLOGY (SHENZHEN) CO., LTD.	2400-000146-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	SHENZHEN CLICK TECHNOLOGY Co., LTD	2400-000146-0000	Class B	IEC/EN 62109-1	Test in appliance
--Bobbin	CHANG CHUN PLASTICS CO LTD		V-0, 150°C, Min. 0.51mm thickness	UL 94, UL 746C	UL E59481
--Insulation tape	JINGJIANG YAHUA PRESSURE SENSITIVE GLUE CO LTD	PF	130°C	UL 510	UL E165111
--Margin tape	YUEYANG GREEN TECHNOLOGY CO.,LTD OR EQUAL	PF	130°C	UL 510	UL E165111
--Magnet wire	GUANGZHOU WANBAO ENAMELLED CO.,LTD OR EQUAL	UEW 130°C	155°C	UL 1446	UL E167402
--Varnish	HANG CHEUNG PETROCHEMICAL LTD OR EQUAL	8562(a)	155°C	UL 1446	UL E200154

IEC/EN 62109-1					
Clause	Requirement – Test			Result - Remark	Verdict
--Varnish	JOHN C DOLPH CO	BC-346A	Min. 200°C	UL 1446	UL E317427
PCB	DONGGUAN XINGLIAN ELECTRONIC TECHNOLOGY CO., LTD	KB	V-0, 130°C	CQC, SGS	TS16949
Thermistor (NTC4-HS3, NTC8-HS1)	LATTRON CO LTD	CWF4 15KH4150	15Kohm at 25°C	UL 1434	UL E306546
IGBT (Q28, Q27, Q29, Q30, Q32)	--	--	50A, 60A/650V	--	--
(Alternate)	--	--	75A, 80A/650V	--	--
IGBT (QA1, QB2, QC1, QD2)	--	--	75A, 80A/600V	--	--
MOSFET (Q42, Q44, Q45, Q58)	--	--	270A, 60V	--	--
MOSFET (Q11, Q12, Q13, Q14, Q17, Q18, Q19, Q20, Q21, Q22, Q23, Q24, Q25, Q26, Q38, Q40)	--	--	201A, 80V	--	--
(Alternate)	--	--	160A, 85V	--	--
(Alternate)	--	--	210A, 60V	--	--
DC fuse (F3)	LITTELFUSE AUTOMOTIVE GMBH	BTF1	150A, 58Vdc	UL 248-1 UL 248-14	UL E211637
(Alternate)	Interchangeable	Interchangeable	V-0 or better, Min. 130°C	UL94	UL
For inverter CNTL board (250-00625-01)					
MCU	TI	TMS320F28335 LQFP	--	--	--
PCB	SHENZHEN HONGMY PRECISION CIRCUIT CO LTD	KB	V-0, 130°C	CQC、SGS	---
For MPPT charger main board (2500-010519-00XX)					

IEC/EN 62109-1					
Clause	Requirement – Test			Result - Remark	Verdict
Opto coupler (45)	COSMO ELECTRONICS CORP	PC817	Int. CR / Ext. CR / Dti. $\geq 6,5$ mm / $\geq 6,5$ mm / $> 0,4$ mm, 55/115/21	IEC 60747-5-2:1997 + A1:2002	VDE 101347 UL E169586
Relay (K1, K2)	SONG CHUAN PRECISION CO.,LTD	897P-1AH-C	12Vdc,70A	--	--
Transformer (T1)	SHENZHEN YAMAXI ELECTRONICS TECHNOLOGY CO., LTD	2400-000229-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	Shenzhen Jsy TECHNOLOGY CO., LTD	2400-000229-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	JEPULS TECHNOLOGY (SHENZHEN) CO., LTD.	2400-000229-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	SHENZHEN CLICK TECHNOLOGY CO., LTD	2400-000229-0000	Class B	IEC/EN 62109-1	Test in appliance
--Bobbin	CHANG CHUN PLASTICS CO LTD	T375J	130°C	UL 94	UL E41429
--Insulation tape	JINGJIANG YAHUA PRESSURE SENSITIVE GLUE CO LTD	PZ	130°C	UL 510	UL E165111
--Margin tape	JINGJIANG YAHUA PRESSURE SENSITIVE GLUE CO LTD	WF	130°C	UL 510	UL E165111
--Magnet wire	PACIFIC ELECTRONICS WIRE&CABLE CO LTD	xUEW-U	130°C	UL 1446	UL E201757
--Tubing	FLUO TECH INDUSTRIES CO.,LTD	E175982	300V, 200°C	UL 224	UL E64007
MOSFET (Q11, Q12, Q19, Q21, Q13, Q14, Q20, Q25)	--	IRFB4115PBF	104A, 150V	--	--

IEC/EN 62109-1					
Clause	Requirement – Test			Result - Remark	Verdict
(Alternate)	--	FDP075N15A	92A, 150V	--	--
DIODE (D56, D57, D59, D60)		VS-80CPU02-F3	80A, 200V		
PCB	SHENZHEN HONGMY PRECISION CIRCUIT CO LTD	KB	V-0, 130°C	CQC, SGS	---
(Alternate)	Interchangeable	Interchangeable	V-0 or better, Min. 130°C	UL94	UL
Opto coupler (U7, U1, U4)	COSMO ELECTRONICS CORP	K1010	Int. CR / Ext. CR / Dti. ≥6,5 mm / ≥6,5mm / >0,4 mm, 55/115/21	IEC 60747-5-2:1997 + A1:2002	VDE 101347 UL E169586
MCU	TI	TMS320F28034 PN	--	--	--
For communication board (250-00418-01)					
RY2	Xiamen Hongfa Electroacoustic Co., Ltd.	HF32FA/005-ZS2	3A, 30VDC	VDE0700/0631	VDE (40006182) UL(E134517)
PCB	DONGGUAN XINGLIAN ELECTRONIC TECHNOLOGY CO., LTD	GUOJI	V-0, 130°C	CQC, SGS	--
(Alternate)	Interchangeable	Interchangeable	V-0 or better, Min. 130°C	UL94	UL
For parallel board (2500-010450-00XX)					
Transformer (TX1)	SHENZHEN YAMAXI ELECTRONICS CO., LTD	2400-000155-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	Shenzhen Jsy TECHNOLOGY CO., LTD	2400-000155-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	JEPULS TECHNOLOGY (SHENZHEN) CO., LTD.	2400-000155-0000	Class B	IEC/EN 62109-1	Test in appliance
(Alternate)	SHENZHEN FERROCOIL ELECTRONICS TECHNOLOGY CO., LTD	2400-000155-0000	Class B	IEC/EN 62109-1	Test in appliance

IEC/EN 62109-1					
Clause	Requirement – Test			Result - Remark	Verdict
-Triple insulated wire	FURUKAWA ELECTRIC CO., LTD	TEX-E	130°C	UL 2353	UL E206440
Opto coupler (U3, U5)	COSMO ELECTRONICS CORP	K1010	Int. CR / Ext. CR / Dti. $\geq 6,5$ mm / $\geq 6,5$ mm / $> 0,4$ mm, 55/115/21	IEC 60747-5-2: 1997 + A1: 2002	VDE(101347) UL(E169586)
Alternate	COSMO Electronics Corporation	KPC 357 NT	Int. CR / Ext. CR / Dti. $\geq 6,5$ mm / $\geq 6,5$ mm / $> 0,4$ mm, Min. 100°C	DIN EN 60747-5-2: 2001-01	VDE 40014684
Opto coupler (IC1, IC2, IC3)	VISHAY	SFH6156-3			UL(1577), VDE(0884-5)
PCB	SHENZHEN JINJIAXING ELECTRONICS CO., LTD	GUOJI	CQC, SGS	CQC, SGS	
(Alternate)	Interchangeable	Interchangeable	V-0 or better, Min. 130°C	UL94	UL
Note:					

TEST REPORT
IEC 62109-2
Safety of Power Converter for use in Photovoltaic Power Systems
Part 2: Particular requirements for inverters

Report Number..... : ENS2301060040S00201R

Date of issue : See page 2

Total number of pages : See page 2

Testing Laboratory name..... EMTEK (SHENZHEN) CO., LTD.

Bldg 69, Majialong Industry Zone, Nanshan District, Shenzhen,
Guangdong, China

Applicant's name MUST ENERGY (GUANGDONG) TECHNOLOGY CO., LTD

Address..... 1-5F, 7F, 9F, 10F of No.8 building, No.115, Zhangcha Road 1,
Chancheng district, Foshan city, Guangdong Province, P.R.China

Test specification:

Standard IEC 62109-2:2011, EN 62109-2:2011

Test procedure..... LVD

Non-standard test method.....: N/A

Test Report Form No...... IEC62109_2B

Test Report Form(s) Originator.... LCIE - Laboratoire Central des Industries Electriques

Master TRF Dated 2016-11

Copyright © 2016 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Test item description	ENERGY STORAGE INVERTER
Trade Mark	MUST
Manufacturer	MUST ENERGY (GUANGDONG) TECHNOLOGY CO., LTD
Address.....	1-5F, 7F, 9F, 10F of No.8 building, No.115, Zhangcha Road 1, Chancheng district, Foshan city, Guangdong Province, P.R.China
Model/Type reference.....	HBP18-2024 HM, HBP18-3024 HM, HBP18-3524 HM, HBP18-4048 HM, HBP18-5248 HM, HBP18-5548 HM, HBP18-5248 PRO, HBP18-5548 PRO, HBP18-52481 PRO, HBP18-52482 PRO, HBP18-52483 PRO, HBP18-52484 PRO, HBP18-52485PRO, HBP18-55481 PRO, HBP18-55482 PRO, HBP18-55483 PRO, HBP18-55484 PRO, HBP18-55485 PRO
Ratings.....	See the rating labels.



Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
<input checked="" type="checkbox"/>	CB Testing Laboratory:	EMTEK (Shenzhen) Co., Ltd
Testing location/ address		Bldg 69, Majialong Industry Zone, Nanshan District, Shenzhen, Guangdong, China
Tested by (name, function, signature).....		Cloud Cui / Engineer See page 4
Approved by (name, function, signature) ..		Angel Lan / Manager See page 4
<hr/>		
<input type="checkbox"/>	Testing procedure: CTF Stage 1:	
Testing location/ address		
Tested by (name, function, signature).....		
Approved by (name, function, signature) ..		
<hr/>		
<input type="checkbox"/>	Testing procedure: CTF Stage 2:	
Testing location/ address		
Tested by (name + signature).....		
Witnessed by (name, function, signature) . :		
Approved by (name, function, signature) .. :		
<hr/>		
<input type="checkbox"/>	Testing procedure: CTF Stage 3:	
<input type="checkbox"/>	Testing procedure: CTF Stage 4:	
Testing location/ address		
Tested by (name, function, signature).....		
Witnessed by (name, function, signature) . :		
Approved by (name, function, signature) .. :		
Supervised by (name, function, signature) :		
<hr/>		

Summary of testing:

- The product has been tested according to standard IEC 62109-1:2010, EN 62109-1:2010 & IEC 62109-2:2011, EN 62109-2:2011.
- Tested for moderate conditions
- EUT is designed for altitudes not exceeding 2000 m.

List of Attachments (including a total number of pages in each attachment):

This test report contains 2 parts listed in below table:

Item	Description	Pages
Part 1	IEC/EN62109-1: 2010 Test report	2-65
Part 2	IEC/EN62109-2: 2011 Test report	66-98



Test item particulars:	
Classification of installation and use.....:	Fixed, permanent connection, indoor, OVC III for mains, OVC II for PV
Connection to the mains	<input type="checkbox"/> pluggable equipment <input type="checkbox"/> direct plug-in <input checked="" type="checkbox"/> permanent connection <input type="checkbox"/> for building-in
Possible test case verdicts:	
- test case does not apply to the test object	: N(/A, Not applicable)
- test object does meet the requirement.....	: P (Pass)
- test object does not meet the requirement.....	: F (Fail)
Testing	
Date of receipt of test item	: (See page 6)
Date (s) of performance of tests.....	: (See page 6)
General remarks:	
<p>"(see Attachment #)" refers to additional information appended to the report. "(see appended table)" refers to a table appended to the report. The tests results presented in this report relate only to the object tested. This report shall not be reproduced except in full without the written approval of the testing laboratory. List of test equipment must be kept on file and available for review. Additional test data and/or information provided in the attachments to this report. Throughout this report a <input type="checkbox"/> comma / <input checked="" type="checkbox"/> point is used as the decimal separator.</p>	
General product information:	
(See page 7)	
Copy of marking plate:	
(See page 8-9)	

IEC 62109-2			
Clause	Requirement – Test	Result - Remark	Verdict
4	GENERAL TESTING REQUIREMENTS		P
4.4.4	Single fault conditions to be applied		N/A
4.4.4.15	Fault-tolerance of protection for grid-interactive inverters		N/A
4.4.4.15.1	Fault-tolerance of residual current monitoring according to 4.8.3.5: the residual current monitoring system operates properly		N/A
	Where protection against hazardous residual currents according to 4.201.3.1.4 is required, the residual current monitoring system must be able to operate properly with a single fault applied, or must detect the fault or loss of operability and cause the inverter to indicate a fault and disconnect from or not connect to the MAINS, no later than the next attempted re-start.		N/A
	Compliance is checked by testing with the grid-interactive inverter connected as in reference test conditions in Part 1. Single faults are to be applied in the inverter one at a time, for example in the residual current monitoring circuit, other control circuits, or in the power supply to such circuits. For each fault condition, the inverter complies if one of the following occurs:		N/A
	a) the inverter ceases to operate, indicates a fault in accordance with 13.9, disconnects from the mains, and does not re-connect after any sequence of removing and reconnecting PV power, AC power, or both,		N/A
	or b) the inverter continues to operate, passes testing in accordance with 4.201.3.1.4 showing that the residual current monitoring system functions properly under the single fault condition, and indicates a fault;		N/A
	or c) the inverter continues to operate, regardless of loss of residual current monitoring functionality, but does not re-connect after any sequence of removing and reconnecting PV power, AC power, or both, and indicates a fault.		N/A
4.4.4.15.2	Fault-tolerance of automatic disconnecting means		N/A
4.4.4.15.2.1	The means provided for automatic disconnection of a grid-interactive inverter from the mains shall:		N/A
	- disconnect all grounded current-carrying conductors from the mains		N/A
	- disconnect all ungrounded current-carrying conductors from the mains		N/A

IEC 62109-2			
Clause	Requirement – Test	Result - Remark	Verdict
	- be such that with a single fault applied to the disconnection means or to any other location in the inverter, at least basic insulation or simple separation is maintained between the PV array and the mains when the disconnecting means is intended to be in the open state.		N/A
4.4.4.15.2.2	Design of insulation or separation complies with requirements of 7.3.7 of Part 1: report here Part 1 comment and verdict.		N/A
4.4.4.15.2.3	For non-isolated inverter, automatic checking of the isolation provided by a disconnect means after single fault.		N/A
	If the check fail: - any still-functional disconnection means shall be left in the open position		N/A
	- at least basic or simple separation shall be maintained between the PV input and the mains		N/A
	- the inverter shall not start operation		N/A
	- the inverter shall indicate a fault in accordance with 13.9		N/A
4.4.4.16	A stand-alone inverter with a transfer switch to transfer AC loads from the mains or other AC bypass source to the inverter output:		N/A
	- shall continue to operate normally		N/A
	- shall not present a risk of fire as the result of an out-of-phase transfer		N/A
	- shall not present a risk of shock as the result of an out-of-phase transfer		N/A
	- And having control preventing switching: components for malfunctioning		N/A
4.4.4.17	Cooling system failure – Blanketing test No hazards according to the criteria of sub-clause 4.4.3 of Part 1 shall result from blanketing the inverter This test is not required for inverters restricted to use only in closed electrical operating areas.		P
	Test stop condition: time duration value or stabilized temperature		P
4.7	ELECTRICAL RATINGS TESTS		P
4.7.4	Stand-alone Inverter AC output voltage and frequency		P
4.7.4.1	General		P
4.7.4.2	Steady state output voltage at nominal DC input The steady-state AC output voltage shall not be less than 90 % or more than 110 % of the rated nominal voltage with the inverter supplied with its nominal value of DC input voltage.		P
4.7.4.3	Steady state output voltage across the DC input range The steady-state AC output voltage shall not be less than 85 % or more than 110 % of the rated		P

IEC 62109-2			
Clause	Requirement – Test	Result - Remark	Verdict
	nominal voltage with the inverter supplied with any value within the rated range of DC input voltage.		
4.7.4.4	Load step response of the output voltage at nominal DC input The AC output voltage shall not be less than 85 % or more than 110 % of the rated nominal voltage for more than 1,5 s after application or removal of a resistive load.		P
4.7.4.5	Steady state output frequency The steady-state AC output frequency shall not vary from the nominal value by more than +4 % or –6 %.		P
4.7.5	Stand-alone inverter output voltage waveform		P
4.7.5.1	General		P
4.7.5.2	The AC output voltage waveform of a sinusoidal output stand-alone inverter shall have a total harmonic distortion (THD) not exceeding of 10 % and no individual harmonic at a level exceeding 6 %.		P
4.7.5.3	Non-sinusoidal output waveform requirements		N/A
4.7.5.3.1	General		N/A
4.7.5.3.2	The total harmonic distortion (THD) of the voltage waveform shall not exceed 40 %.		N/A
4.7.5.3.3	The slope of the rising and falling edges of the positive and negative half-cycles of the voltage waveform shall not exceed 10 V/μs measured between the points at which the waveform has a voltage of 10 % and 90 % of the peak voltage for that half-cycle.		N/A
4.7.5.3.4	The absolute value of the peak voltage of the positive and negative half-cycles of the waveform shall not exceed 1,414 times 110 % of the RMS value of the rated nominal AC output voltage.		N/A
4.7.5.4	Information requirements for non-sinusoidal waveforms The instructions provided with a stand-alone inverter not complying with 4.7.5.2 shall include the information in 5.3.2.6.		N/A
4.7.5.5	Output voltage waveform requirements for inverters for dedicated loads. For an inverter that is intended only for use with a known dedicated load, the following requirements may be used as an alternative to the waveform requirements in 4.7.5.2 to 4.7.5.3.		N/A
	The combination of the inverter and dedicated load shall be evaluated to ensure that the output waveform does not cause any hazards in the load equipment and inverter, or cause the load equipment to fail to comply with the applicable product safety standards.		N/A
	The inverter shall be marked with symbols 9 and 15 of Table C.1 of Part 1.		N/A
	The installation instructions provided with the inverter shall include the information in 5.3.2.13.		N/A

IEC 62109-2			
Clause	Requirement – Test	Result - Remark	Verdict
4.8	ADDITIONAL TESTS FOR GRID-INTERACTIVE INVERTERS		N/A
4.8.1	General requirements regarding inverter isolation and array grounding		N/A
	- Type of Array grounding supported		N/A
	- Inverter isolation		N/A
4.8.2	Array insulation resistance detection for inverters for ungrounded and functionally grounded arrays		N/A
4.8.2.1	Array insulation resistance detection for inverters for ungrounded arrays		N/A
	Inverter shall have means to measure DC insulation resistance from PV input (array) to ground before starting operation		N/A
	Or Inverter shall be provided with instruction in accordance with 5.3.2.11.		N/A
	Measured DC insulation resistance:		N/A
	Inverter measurement circuit shall be capable of detecting insulation resistance below the limit value $R = V_{max}/30mA$ under normal conditions		N/A
	Inverter measurement circuit shall be capable of detecting insulation resistance below the limit value $R = V_{max}/30mA$ with ground fault in the PV array		N/A
	Isolated inverters shall indicate a fault if the insulation resistance is less than the limit value		N/A
	Isolated inverter fault indication maintained until insulation resistance has recovered to a value higher than the limit value		N/A
	Non-isolated inverters, or inverters with isolation not complying with the leakage current limits in the minimum inverter isolation requirements in Table 30:		N/A
	- shall indicate a fault in accordance with 13.9		N/A
	- shall not connect to the mains		N/A
4.8.2.2	Array insulation resistance detection for inverters for functionally grounded arrays		N/A
	a-1) The value of the total resistance, including the intentional resistance for array functional grounding, the expected insulation resistance of the array to ground, and the resistance of any other networks connected to ground (for example measurement networks) must not be lower than $R = (V_{MAX PV}/30 mA)$ ohms.		N/A
	a-2) The installation instructions shall include the information required in 5.3.2.12.		N/A
	b-1) As an alternative to a), or if a resistor value lower than in a) is used, the inverter shall incorporate means to detect, during operation, if the total current through the resistor and any networks (for example measurement networks) in parallel with it, exceeds the residual current values and times in Table 31		N/A
	b-2) Inverter shall either disconnect the resistor or limit the current by other means		N/A

IEC 62109-2			
Clause	Requirement – Test	Result - Remark	Verdict
	b-3) If the inverter is a non-isolated inverter, or has isolation not complying with the leakage current limits in the minimum inverter isolation requirements in Table 30, it shall also disconnect from the mains.		N/A
	c) The inverter shall have means to measure the DC insulation resistance from the PV input to ground before starting operation, in accordance with 4.8.2.1.		N/A
4.8.3	Array residual current detection		N/A
4.8.3.1	General		N/A
4.8.3.2	30 mA touch current type test for isolated inverters		N/A
4.8.3.3	Fire hazard residual current type test for isolated inverters		N/A
4.8.3.4	Protection by application of RCD's		N/A
	- The requirement for additional protection in 4.8.3.1 can be met by provision of an RCD with a residual current setting of 30 mA, located between the inverter and the mains..		N/A
	- The selection of the RCD type to ensure compatibility with the inverter must be made according to rules for RCD selection in Part 1.		N/A
	- The RCD provided integral to the inverter, or		N/A
	- The RCD provided by the installer if details of the rating, type, and location for the RCD are given in the installation instructions per 5.3.2.9.		N/A
4.8.3.5	Protection by residual current monitoring		N/A
4.8.3.5.1	General		N/A
	Where required by Table 30, the inverter shall provide residual current monitoring that functions whenever the inverter is connected to the mains with the automatic disconnection means closed.		N/A
	The residual current monitoring means shall measure the total (both a.c. and d.c. components) RMS current.		N/A
	As indicated in Table 30 for different inverter types, array types, and inverter isolation levels, detection may be required for excessive continuous residual current, excessive sudden changes in residual current, or both, according to the following limits:	continuous output power rating \leq 30 kVA;	N/A
	a) Continuous residual current: The inverter shall disconnect within 0,3 s and indicate a fault in accordance with 13.9 if the continuous residual current exceeds:		N/A
	- maximum 300 mA for inverters with continuous output power rating \leq 30kV;		N/A
	- maximum 10 mA per kVA of rated continuous output power for inverters with continuous output power rating > 30 kVA.		N/A
	The inverter may attempt to re-connect if the array insulation resistance meets the limit in 4.8.2.		N/A
	b) Sudden changes in residual current: The inverter shall disconnect from the mains within the time specified in Table 31		N/A

IEC 62109-2			
Clause	Requirement – Test	Result - Remark	Verdict
	The inverter indicates a fault in accordance with 13.9, if a sudden increase in the RMS residual current is detected exceeding the value in the table.		N/A
	The inverter may attempt to re-connect if the array insulation resistance meets the limit in 4.8.2.		N/A
4.8.3.5.2	Test for detection of excessive continuous residual current: test repeated 5 times and time to disconnect shall not exceed 0,3 s.		N/A
4.8.3.5.3	Test for detection of sudden changes in residual current repeated 5 times and each of the 5 results shall not exceed the time limit indicated in for each row (30mA, 60mA and150mA) of Table 31.		N/A
4.8.3.6	Systems located in closed electrical operating areas		N/A
	The protection against shock hazard is not required if the installation information provided with the inverter indicates the restriction for use in a closed electrical operating area, and		N/A
	Installation information indicates what forms of shock hazard protection are and are not provided integral to the inverter, in accordance with 5.3.2.7.		N/A
	The inverter shall be marked as in 5.2.2.6.		N/A

5	MARKING AND DOCUMENTATION		P
5.1	Marking		P
5.1.4	Equipment ratings		P
	PV input ratings:	See below	P
	- Vmax PV (absolute maximum) (d.c. V)	450V d.c	P
	- Isc PV (absolute maximum) (d.c. A)	See label	P
	a.c. output ratings:	See below	P
	- Voltage (nominal or range) (a.c. V)	230 a.c. V	P
	- Current (maximum continuous) (a.c. A)	See label	P
	- Frequency (nominal or range) (Hz)	50/60Hz	P
	- Power (maximum continuous) (W or VA)	See label	P
	- Power factor range	1.0	P
	a.c input ratings:		P
	- Voltage (nominal or range) (a.c. V)	230VAC	P
	- Current (maximum continuous) (a.c. A)	60A	P
	- Frequency (nominal or range) (Hz)	50/60Hz	P
	d.c. output ratings:		P
	- Voltage (nominal or range) (d.c. V)	48Vdc	P
	- Current (maximum continuous) (d.c. A)	See label	P

IEC 62109-2			
Clause	Requirement – Test	Result - Remark	Verdict
	Protective class (I or II or III)	Class I	P
	Ingress protection (IP) rating per part 1	IP20	P
	An inverter that is adjustable for more than one nominal output voltage shall be marked to indicate the particular voltage for which it is set when shipped from the factory.		N/A
5.2	Warning markings		P
5.2.2	Content for warning markings		P
5.2.2.6	Inverters for closed electrical operating areas		N/A
	Where required by 4.8.3.6, an inverter not provided with full protection against shock hazard on the PV array shall be marked with a warning that the inverter is only for use in a closed electrical operating area, and referring to the installation instructions.		N/A
5.3	Documentation		P
5.3.2	Information related to installation		P
5.3.2.1	Ratings. Subclause 5.3.2 of Part 1 requires the documentation to include ratings information for each input and output. For inverters this information shall be as in Table 33 below. Only those ratings that are applicable based on the type of inverter are required.		P
	- Vmax PV (absolute maximum) (d.c. V)		P
	- PV input operating voltage range (d.c. V)		P
	- Maximum operating PV input current (d.c. A)		P
	- Isc PV (absolute maximum) (d.c. A)		P
	- Max. inverter backfeed current to the array (a.c. or d.c. A)		P
	a.c. output quantities:		P
	- Voltage (nominal or range) (a.c. V)		P
	- Current (maximum continuous) (a.c. A)		P
	- Current (inrush) (a.c. A, peak and duration)		P
	- Frequency (nominal or range) (Hz)		P
	- Power (maximum continuous) (W or VA)		P
	- Power factor range		P
	- Maximum output fault current (a.c. A, peak and duration or RMS)		P
	- Maximum output overcurrent protection (a.c. A)		P
	a.c. input quantities:		N/A
	- Voltage (nominal or range) (a.c. V)		N/A
	- Current (maximum continuous) (a.c. A)		N/A
	- Current (inrush) (a.c. A, peak and duration)		N/A

IEC 62109-2			
Clause	Requirement – Test	Result - Remark	Verdict
	- Frequency (nominal or range) (Hz)		N/A
	d.c input (other than PV) quantities:		P
	- Voltage (nominal or range) (d.c. V)		P
	- Nominal battery voltage (d.c. V)		P
	- Current (maximum continuous) (d.c. A)		P
	d.c. output quantities:		N/A
	- Voltage (nominal or range) (d.c. V)		N/A
	- Nominal battery voltage (d.c. V)		N/A
	- Current (maximum continuous) (d.c. A)		N/A
	Protective class (I or II or III)	Class I	P
	Ingress protection (IP) rating per part 1	IP20	P
5.3.2.2	Grid-interactive inverter setpoints		N/A
	For a grid-interactive unit with field adjustable trip points, trip times, or reconnect times, the presence of such controls, the means for adjustment, the factory default values, and the limits of the ranges of adjustability shall be provided in the documentation for the PCE or in other format such as on a website. Provided solution:		N/A
	The setting of field adjustable setpoints shall be accessible from the PCE		N/A
5.3.2.3	Transformers and isolation		N/A
	whether an internal isolation transformer is provided, and if so, what level of insulation (functional, basic, reinforced, or double) is provided by that transformer. The instructions shall also indicate what the resulting installation requirements are regarding such things as earthing or not earthing the array, providing external residual current detection devices, etc.		N/A
	An inverter shall be provided with information to the installer regarding:		N/A
	- providing of internal isolation transformer		N/A
	- the level of insulation (functional, basic, reinforced, or double)		N/A
	The instructions shall also indicate what the resulting installation requirements are regarding:		N/A
	- earthing or not earthing the array		N/A
	- providing external residual current detection devices		N/A
	- requiring an external isolation transformer,		N/A
5.3.2.4	Transformers required but not provided		N/A
	An inverter that requires an external isolation transformer not provided with the unit, shall be provided with instructions that specify, and for the external isolation transformer with which it is intended to be used:		N/A

IEC 62109-2			
Clause	Requirement – Test	Result - Remark	Verdict
	- the configuration type		N/A
	- electrical ratings		N/A
	- environmental ratings		N/A
5.3.2.5	PV modules for non-isolated inverters		N/A
	Non-isolated inverters shall be provided with installation instructions that require PV modules that have an IEC 61730 Class A rating		N/A
	If the maximum AC mains operating voltage is higher than the PV array maximum system voltage then the instructions shall require PV modules that have a maximum system voltage rating based upon the AC mains voltage.		N/A
5.3.2.6	Non-sinusoidal output waveform information		N/A
	The instruction manual for a stand-alone inverter not complying with 4.7.5.2 shall include a warning that:		N/A
	- the waveform is not sinusoidal,		N/A
	- some loads may experience increased heating,		N/A
	- the user should consult the manufacturers of the intended load equipment before operating that load with the inverter		N/A
	The inverter manufacturer shall provide information regarding:		N/A
	- what types of loads may experience increased heating		N/A
	- recommendations for maximum operating times with such loads		N/A
	The inverter manufacturer shall specify for the waveforms as determined by the testing in 4.7.5.3.2 through 4.7.5.3.4.:		N/A
	- THD		N/A
	- slope		N/A
	- peak voltage		N/A
5.3.2.7	Systems located in closed electrical operating areas		N/A
	Where required by 4.8.3.6, an inverter not provided with full protection against shock hazard on the PV array shall be provided with installation instructions:		N/A
	- requiring that the inverter and the array must be installed in closed electrical operating areas		N/A
	- indicating which forms of shock hazard protection are and are not provided integral to the inverter (for example the RCD, isolation transformer complying with the 30 mA touch current limit, or residual current monitoring for sudden changes)		N/A
5.3.2.8	Stand-alone inverter output circuit bonding		N/A
	Where required by 7.3.10, the documentation for an inverter shall include the following:		N/A
	- if output circuit bonding is required but is not provided integral to the inverter, the required means shall be described in the installation		N/A

IEC 62109-2			
Clause	Requirement – Test	Result - Remark	Verdict
	instructions, including which conductor is to be bonded and the required current carrying capability or cross-section of the bonding means;		
	- if the output circuit is intended to be floating, the documentation for the inverter shall indicate that the output is floating.		N/A
5.3.2.9	Protection by application of RCD's		N/A
	Where the requirement for additional protection in 4.8.3.1 is met by requiring an RCD that is not provided integral to the inverter, as allowed by 4.8.3.4, the installation instructions shall state the need for the RCD.		N/A
	and shall specify its rating, type, and required circuit location		N/A
5.3.2.10	Remote indication of faults	See below.	P
	The installation instructions shall include an explanation of how to properly make connections to (where applicable), and use, the electrical or electronic fault indication required by 13.9.	The instructions are specified "Warning List" of the product manual.	P
5.3.2.11	External array insulation resistance measurement and response	Integrated resistance measurement inside	N/A
	The installation instructions for an inverter for use with ungrounded arrays that does not incorporate all the aspects of the insulation resistance measurement and response requirements in 4.8.2.1, must include:		N/A
	- for isolated inverters: an explanation of what aspects of array insulation resistance measurement and response are not provided, and		N/A
	- an instruction to consult local regulations to determine if any additional functions are required or not;		N/A
	- for non-isolated inverters: an explanation of what external equipment must be provided in the system, and		N/A
	- what the setpoints and response implemented by that equipment must be, and:		N/A
	- how that equipment is to be interfaced with the rest of the system.		N/A
5.3.2.12	Array functional grounding information		N/A
	Where approach a) of 4.8.2.2 is used, the installation instructions for the inverter shall include all of the following:		N/A
	Where approach a) of 4.8.2.2 is used, the installation instructions for the inverter shall include all of the following:		N/A
	Where approach a) of 4.8.2.2 is used, the installation instructions for the inverter shall include all of the following:		N/A
	Where approach a) of 4.8.2.2 is used, the installation instructions for the inverter shall include all of the following:		N/A
	Where approach a) of 4.8.2.2 is used, the installation instructions for the inverter shall include		N/A

IEC 62109-2			
Clause	Requirement – Test	Result - Remark	Verdict
	all of the following:		
5.3.2.13	Stand-alone inverters for dedicated loads		N/A
	Where the approach of 4.7.5.5 is used, the installation instructions for the inverter shall include a warning that the inverter is only to be used with the dedicated load for which it was evaluated, and shall specify the dedicated load.		N/A
5.3.2.14	Identification of firmware version(s)	See below	P
	An inverter utilizing firmware for any protective functions shall provide means to identify the firmware version.		P
	This can be a marking, but the information can also be provided by a display panel, communications port or any other type of user interface.....	The Voltage, powers displayed on LCD display panel.	P

7	PROTECTION AGAINST ELECTRIC SHOCK AND ENERGY HAZARDS		P
7.3	Protection against electric shock		P
7.3.10	Additional requirements for stand-alone inverters		P
	Depending on the supply earthing system that a stand-alone inverter is intended to be used with or to create, the output circuit may be required to have one circuit conductor bonded to earth to create a grounded conductor and an earthed system.		P
	One circuit conductor bonded to earth to create a grounded conductor and an earthed system.		P
	The means used to bond the grounded conductor to protective earth provided within the inverter or as part of the installation		P
	If not provided integral to the inverter, the required means shall be described in the installation instructions as per 5.3.2.8.		P
	The means used to bond the grounded conductor to protective earth shall comply with the requirements for protective bonding in Part 1,		P
	If the bond can only ever carry fault currents in stand-alone mode, the maximum current for the bond is determined by the inverter maximum output fault current.		N/A
	Output circuit bonding arrangements shall ensure that in any mode of operation, the system only has the grounded circuit conductor bonded to earth in one place at a time..		P
	Switching arrangements may be used, in which case the switching device used is to be subjected to the bond impedance test along with the rest of the bonding path		N/A
	Inverters intended to have a circuit conductor bonded to earth shall not impose any normal		P

IEC 62109-2			
Clause	Requirement – Test	Result - Remark	Verdict
	current on the bond except for leakage current.		
	Outputs that are intentionally floating with no circuit conductor bonded to ground, must not have any voltages with respect to ground that are a shock hazard in accordance with Clause 7 of Parts 1 and 2.		P
	The documentation for the inverter shall indicate that the output is floating as per 5.3.2.8.		P
7.3.11	Functionally grounded arrays	No such parts.	N/A
	All PV conductors in a functionally grounded array shall be treated as being live parts with respect to protection against electric shock.		N/A

9	PROTECTION AGAINST FIRE HAZARDS		P
9.3	Short-circuit and overcurrent protection		P
9.3.4	Inverter backfeed current onto the array		P
	The backfeed current testing and documentation requirements in Part 1 apply, including but not limited to the following.		
	Inverter backfeed current onto the PV array maximum value.....		P
	This inverter backfeed current value shall be provided in the installation instructions regardless of the value of the current, in accordance with Table 33.		P

13	PHYSICAL REQUIREMENTS		P
13.9	Fault indication		P
	Where this Part 2 requires the inverter to indicate a fault, both of the following shall be provided:		P
	a) a visible or audible indication, integral to the inverter, and detectable from outside the inverter, and		P
	b) an electrical or electronic indication that can be remotely accessed and used.		P
	The installation instructions shall include information regarding how to properly make connections (where applicable) and use the electrical or electronic means in b) above, in accordance with 5.3.2.10.		P

IEC 62109-2			
Clause	Requirement – Test	Result - Remark	Verdict

4.4.4	TABLE: Single fault condition to be applied					N/A
	Ambient temperature (°C)					—
	Power source for EUT: Manufacturer, model/type, output rating	--				—
4.4.4.15.1	Fault-tolerance of residual current monitoring					
Component No.	Fault	Supply voltage (V)	Test time	Fuse #	Fuse current (A)	Observation
Check that the residual current monitoring operates properly						
Supplementary information:						

4.4.4	TABLE: Single fault condition to be applied					N/A
	Ambient temperature (°C)	25				—
	Power source for EUT: Manufacturer, model/type, output rating	--				—
4.4.4.15.2	Fault-tolerance of automatic disconnecting means					
Component No.	Fault	Supply voltage (V)	Test time	Fuse #	Fuse current (A)	Observation
Check that the relays fulfil the basic insulation or simple separation based on the PV circuit working voltage.						
Each active phase can be switched. (L and N)						Yes
Supplementary information:						

4.4.4.17	Cooling system failure – Blanketing test	P
----------	---	----------

IEC 62109-2			
Clause	Requirement – Test	Result - Remark	Verdict

	Test voltage (Vdc)	48	—
	Test current (Idc)	115.0	—
	Test voltage (Vac).....	230	—
	Test current (Iac)	23.94	—
	t _{amb1} (°C)	55.0	—
	t _{amb2} (°C)	55.2	—
maximum temperature T of part/at::		T (°C)	T_{max} (°C)
1.	Enclosure (Top)	68.2	90
2.	Enclosure (Side)	67.9	90
3.	Enclosure (Bottom)	70.2	90
4.	LCD panel	68.6	90
5.	Ambient	55.0	--

Supplementary information:

4.7.4	TABLE: Steady state Inverter AC output voltage and frequency		P
	Nominal DC input (V)	48VDC	
	Nominal output AC voltage (V) :	230VAC	
AC output U (V)	Frequency (Hz)	Condition/status	Comments
227.9	50	Without load	
223.6	50	Resistive load application	
227.9	50	Resistive load removal	

Supplementary information:

4.8.2	TABLE: Array insulation resistance detection for inverters for ungrounded and functionally grounded arrays				N/A
4.8.2.1	Array insulation resistance detection for inverters for ungrounded arrays				N/A
DC Voltage below minimum operating voltage (V)	DC Voltage for inverter begin operation (V)	Resistance between ground and PV input terminal (Ω)	Required Insulation resistance $R = (V_{MAX PV} / 30mA)$ (Ω)	Result	
DC+					

IEC 62109-2			
Clause	Requirement – Test	Result - Remark	Verdict
DC-			
Note: For isolated inverters, shall indicate a fault in accordance with 13.9 (operation is allowed); the fault indication shall be maintained until the array insulation resistance has recovered to a value higher than the limit above For non-isolated inverters, or inverters with isolation not complying with the leakage current limits in the minimum inverter isolation requirements in Table 30, shall indicate a fault in accordance with 13.9, and shall not connect to the mains; the inverter may continue to make the measurement, may stop indicating a fault and may connect to the mains if the array insulation resistance has recovered to a value higher than the limit above. It is not required to test all PV input terminals if analysis of the design indicates that one or more terminals can be expected to have the same result, for example where multiple PV string inputs are in parallel.			
Supplementary information:			

4.8.3.2	TABLE: 30mA touch current type test for isolated inverters	N/A
Condition	Current (mA)	Limit (30mA)
DC+ to PE		
DC- to PE		
Supplementary information: The touch current measurement circuit of IEC 60990, Figure 4 is connected from each terminal of the array to ground, one at a time.		

4.8.3.3	TABLE: Fire hazard residual current type test for isolated inverters	N/A
Condition	Current (mA)	Limit (300mA or 10mA per kVA)
DC+ to PE		
DC- to PE		
Supplementary information:		

4.8.3.5	TABLE: Protection by residual current monitoring	N/A
Test conditions:	Output power (kVA) : Input voltage (V_{DC}): Frequency (Hz) Output AC Voltage (V_{AC}):	
4.8.3.5.2	Test for detection of excessive continuous residual current	
Fault Current (mA)		Disconnection time (ms)
Measured	Limit	Measured Disconnection time
		Limit

IEC 62109-2			
Clause	Requirement – Test	Result - Remark	Verdict
Fault Current	300mA for output power ≤ 30 kVA 10mA per kVA for output power > 30 kVA		
+ PV to N:			
- PV to N:			
Note: – maximum 300mA for inverters with continuous output power rating ≤30 kVA; – maximum 10mA per kVA of rated continuous output power for inverters with continuous output power rating > 30 kVA. This test shall be repeated 5 times, and for all 5 tests the time to disconnect shall not exceed 0,3s. The test is repeated for each PV input terminal. It is not required to test all PV input terminals if analysis of the design indicates that one or more terminals can be expected to have the same result, for example where multiple PV string inputs are in parallel.			
Supplementary information:			

Pictures



Fig. 1 -- Over view 1



Fig. 2 -- Over view 2

Pictures



Fig. 3 -- Over view 3




Fig. 4 -- Over view 4

Pictures



Fig. 5 -- Terminal view 1



Fig. 6 -- Terminal view 2

Pictures




Fig. 7 -- Internal view



Fig. 8 -- Internal view

Pictures



Fig. 9 -- Component side view




Fig. 10 -- Trace side view

Pictures




Fig. 11 -- Component side view




Fig. 12 -- Trace side view

Pictures




Fig. 13 -- Component side view




Fig. 14 -- Trace side view

Pictures




Fig. 15 -- Component side view




Fig. 16 -- Trace side view

Pictures




Fig. 17 -- Component side view




Fig. 18 -- Trace side view

Pictures



Fig. 19 -- Component side view




Fig. 20 -- Trace side view

Pictures




Fig. 21 -- PCB view 1




Fig. 22 -- PCB view 2

Pictures



Fig. 23 -- Fan View

声明 Statement

1. 本报告无授权批准人签字及“检验检测专用章”无效；

This report is invalid without the signature of the authorized approver and "special seal for testing"

2. 未经许可本报告不得部分复制；

This report shall not be copied partly without authorization.

3. 本报告的检测结果仅对送测样品有效，委托方对样品的代表性和资料的真实性负责；

The test results or observations are applicable only to tested sample. Client shall be responsible for representativeness of the sample and authenticity of the material.

4. 本检测报告中检测项目标注有特殊符号则该项目不在资质认定范围内，仅作为客户委托、科研、教学或内部质量控制等目的使用；

The observations or tests with special mark fall outside the scope of accreditation, and are only used for purpose of commission, research, training, internal quality control etc.

5. 本检测报告以实测值进行符合性判定，未考虑不确定度所带来的风险，本实验室不承担相关责任，特别约定、标准或规范中有明确规定的除外；

The test results or observations are provided in accordance with measured value, without taking risks caused by uncertainty into account. Without explicit stipulation in special agreements, standards or regulations, EMTEK shall not assume any responsibility.

6. 对本检验报告若有异议，请于收到报告之日起 20 日内提出；

Objections shall be raised within 20 days from the date receiving the report.