

Certificate of Compliance



No. 0H191128.ZTESS39

Test Report no. XMT0201901411S/LVD

Certificate's
Holder:

Zhejiang Tongzheng Electric Co., Ltd.
Beishan Village, Huanghua Town, Yueqing City,
Zhejiang Province

Certification ECM
Mark:



Product:
Model(s):

Surge Protective Device
(see the following annex I)

Verification to:

Standard:
EN 61643-11:2012+A11:2018,
IEC 61643-11:2011

related to CE Directive(s):
2014/35/EU (Low Voltage)

Remark: The product(s) has been verified on a voluntary basis. The product(s) satisfies the requirements of the Certification Mark of ECM, in reference to the above listed Standard(s). The above Compliance Mark can be affixed on the product(s) accordingly to the ECM regulation about its release and its use. The regulation can be found at www.entecerma.it. This Certificate of Compliance can be checked for validity at www.entecerma.it

This verification doesn't imply assessment of the production of the product(s).

Additional information, clarification about the **CE** Marking:



We attest that a TCF for the **CE** Marking process is in place. Whereas the Manufacturer is Responsible to start the **CE Marking Certification Procedure** and to perform all the necessary activities, as required by the Directive before placing the **CE** Mark on the product(s).

Date of issue 28 November 2019

Expiry date 27 November 2024

Chief Manager
Marco Morino



Deputy Manager
Amanda Payne



Ente Certificazione Macchine Srl

Via Ca' Bella, 243 - Loc. Castello di Serravalle - 40053 Valsamoggia (BO) - ITALY
 ☎ +39 051 6705141 📠 +39 051 6705156 ✉ info@entecerma.it 🌐 www.entecerma.it

Annex I



No. 0H191128.ZTESS39

Test Report no. XMT0201901411S/LVD

Class II test (PVT2)						
Product Model	Protection Mode	I _{max} (Ka)	I _n (kA)	UCPV(V)	UP(kV)	ISCPV(A)
TZG40-PV DC600V 2P	+ →PE	40	20	600	2.2	100
	- →PE	40	20	600	2.2	100
TZG40-PV DC800V 2P	+ →PE	40	20	800	3.0	100
	- →PE	40	20	800	3.0	100
TZG40-PV DC1000V 2P	+ ↔ -	40	20	1000	3.2	100
	+ →PE	40	20	1000	3.2	100
	- →PE	40	20	1000	3.2	100
TZG40-PV DC1200V 3P	+ ↔ -	40	20	1200	4.0	100
	+ →PE	40	20	1200	4.0	100
	- →PE	40	20	1200	4.0	100

Ente Certificazione Macchine Srl

Via Ca' Bella, 243 - Loc. Castello di Serravalle - 40053 Valsamoggia (BO) - ITALY

☎ +39 051 6705141 📠 +39 051 6705156 ✉ info@entecerma.it 🌐 www.entecerma.it